



From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 16 January 2020 16:52
To: Zac Denton <Zac.Denton@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FG/152/19/PL - 40 Little Paddocks, Ferring, BN12 5NJ

Dear Zac,

In relation to the above application, please may EH comment as follows:

- No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:
 - a) An indicative programme for carrying out of the works;
 - b) Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
 - c) Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
 - d) Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
 - e) The parking of vehicles of site operatives and visitors;
 - f) Loading and unloading of plant and materials, including permitted times for deliveries;
 - g) Storage of plant and materials used in constructing the development;
 - h) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
 - i) The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
 - j) Measures to control the emission of dust and dirt during construction;
 - k) A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

- No construction / demolition activities shall take place, other than between 08:00 to 18:00 hours (Monday to Friday) and 08:00 to 13:00 hours (Saturday) with no noisy work on Sunday or Bank Holidays. **Reason:** To protect the amenity of local residents in accordance with Policy QE SP1 of the adopted Arun Local Plan 2011 – 2031
- No external lighting shall be installed until details have been submitted to, and approved in writing by the Local Planning Authority prior to the commencement of the development. This submission shall include a layout plan with beam orientation and a schedule of light equipment proposed (luminaire type; mounting height; aiming angles and luminaire profiles). The approved scheme shall be installed, fully assessed by a competent individual when operational to ensure no light creep/bleed, maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to the variation. **Reason:** To protect the appearance of the area/the environment and wildlife/local residents from light pollution.

Informatives:

- The applicant's attention is drawn to the requirements of the Environmental Protection Act 1990 and the Clean Air Act 1993 with regard to burning on site. A Statutory Nuisance may be caused by smoke and ash from fires or noise from the cutting or chipping trees. In addition, air quality could be adversely affected on large projects. The granting of this planning permission does not permit a statutory nuisance to be caused. The Environment Agency should also be contacted regarding Exemption Permits to burn on site.
- The granting of this planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of the Environmental Protection Act 1990 be received. For further information, please contact the Environmental Health Department on **01903 737555**.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.