

Amanda Scholes | Receptionist, Department, Arun District Council | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>

Sent: 15 December 2020 15:01

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Anita Gardner <Anita.Gardner@arun.gov.uk>

Subject: RE: Planning Consultation on: FG/153/20/DOC

Dear Anita,

We do not recommend discharge of Condition 2 at this time, and have the following comments:

1. Infiltration testing was completed too deep and not in accordance with BRE365. One test was completed in each location only, and water failed to drain to 25% level. The infiltration tests were completed below groundwater level and not at the depth of the proposed infiltrating features.
2. No calculations have been supplied to support the design.
3. No construction detail drawings have been provided.
4. The layout plan does not detail the required depth of the car park sub-base.
5. The layout plan needs to clearly state whether permeable storage areas are to have flat sub-bases or not.

Please re-consult us once further information has been supplied.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 23 November 2020 14:04

To: Land Drainage

Subject: Planning Consultation on: FG/153/20/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No:	FG/153/20/DOC
Registered:	23rd November 2020
Site Address:	Quercus Nursery Littlehampton Road Ferring BN12 6PG
Description of Works:	Approval of details reserved by condition imposed under ref APP/C3810/W/19/3232525 (FG/35/19/PL) relating to Condition No 2 - surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **7th December 2020**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Mrs A Gardner

Planning Case Officer- Arun District Council

Telephone: 01903 737529

Email: Anita.Gardner@arun.gov.uk

PLCOND00 (ODS) 2020