

**From:** Thomas Callaway  
**Sent:** 24 December 2014 09:35  
**To:** Planning.Responses  
**Subject:** RE: Planning Consultation on: FG/167/14/PL

The applicant states that surface water is to be disposed of to main sewer. Infiltration must be investigated as surface water should not be discharged to the main sewer.

Please apply standard conditions ENGD2A.

Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE 365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have the provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year storm event plus 30% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location.

Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers. Supplementary guidance notes are also enclosed for information.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre,  
Maltravers Road, Littlehampton, BN17 5LP

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: [Thomas.Callaway@arun.gov.uk](mailto:Thomas.Callaway@arun.gov.uk)

Arun is Working in Partnership with Chichester District Council

Visit our web site at [www.arun.gov.uk](http://www.arun.gov.uk) and [www.chichester.gov.uk](http://www.chichester.gov.uk)



Save the environment - think before you print.

**From:** [planning.responses@arun.gov.uk](mailto:planning.responses@arun.gov.uk) [<mailto:planning.responses@arun.gov.uk>]  
**Sent:** 03 December 2014 14:33  
**To:** Thomas Callaway  
**Subject:** Planning Consultation on: FG/167/14/PL

To: **Engineers (Fluvial Flooding)**

**NOTIFICATION FROM ARUN DISTRICT COUNCIL**

**Town & Country Planning Act 1990 (as amended)**

**Town and Country Planning (Development Management Procedure) (England) Order 2010 (as amended)**

**Planning Permission**

**APPLICATION**                      **FG/167/14/PL**

**NO:**

**Registered:**                      19th November  
2014

**Site Address:**                      52-56 Ferring Street Ferring BN12 5JP

**Grid Reference:**                      509498 102858

**Description of Works:**                      Demolition of 52-56 Ferring Street and construction of a two and a half storey building with accommodation in the roof, to provide a mixed use development of 3 No. two bed flats and 2 No. one bed flats and three retail units at ground floor (Use Class A1).

---

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

**Should you have any comments to make, these should be sent by replying to this email by 01-JAN-15.**

You can also monitor the progress of this application through the Council web site:  
[www.arun.gov.uk/planning](http://www.arun.gov.uk/planning)

**Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.**

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:  
[www.planningportal.gov.uk/planning/appeals/](http://www.planningportal.gov.uk/planning/appeals/) but they will protect personal details.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Regards

consultee\_email

---