

WEST SUSSEX COUNTY COUNCIL CONSULTATION

TO:	Arun District Council FAO: Mrs A Gardner	
FROM:	Highways, WSCC	
DATE:	31 October 2018	
LOCATION:	Garage Premises, Littlehampton Road, Ferring, Worthing, BN12 6PB	
SUBJECT:	FG/171/18/DOC Approval of details reserved by condition imposed under FG/39/18/PL relating to conditions 3-surface water drainage, 4-ground contamination risk, 9-position & intensity of lighting filments, 14-lighting scheme, 15-Construction Management Plan & 16-ground contamination risk.	
DATE OF SITE VISIT:		
RECOMMENDATION:	☐ Advice ☐ Objection ☐ Modification ☐ No Objection ☒ More Information ☐ Refusal	
S106 CONTRIBUTION TOTAL:		

Condition 15 – Construction Management Plan

Plans considered; Site Construction Management Plan 17036-HNW-00-XX-D-R-A-W112, Site Demolition Plan, Construction Management Plan (HNW).

Site Setup Plan WSL-2453-CDM01 and Construction Method Statement (CMS) appear to be related to a different scheme. It is not clear as to why they have been submitted as they contain information different from the documents listed above.

Please can the following information be provided:

- Maximum size of delivery vehicles. The CMP states no articulated vehicles will be used however rigid vehicles can have a limited turning circle.
- Swept paths for maximum vehicle size of; the access and of turning within the site. Swept paths should be shown on the CMP with all other obstructions ie parking also shown.
- Details of any extra large plant expected ie Cranes.

Please reconsult

West Sussex County Council – Planning Services