

Lynnyrd Wolfe

From: Anita Gardner
Sent: 04 December 2018 17:26
To: Lynnyrd Wolfe
Subject: FW: FG/171/18/DOC - Honda Garage Premises, Littlehampton Road,

Please scan as a consultee response from environmental health

From: Carol Reynolds
Sent: 04 December 2018 13:33
To: Anita Gardner
Subject: Re: FG/171/18/DOC - Honda Garage Premises, Littlehampton Road,

Dear Anita

Incorrect Construction Management Plan. Please redact EH comment noted against this application which relates to another site and apply the following comment.

Environmental Health: Application for discharge of conditions. Further information required.

*Hours of operation: Information supplied indicates Monday to Saturday working alone (08:00 to 18:00 hours). Please clarify whether works are intended on any Saturday and if so, this to be confirmed as between the hours 08:00 to 13:00 only. No operation to occur at all on any Sunday, Monday or Bank or Public holiday.

*The Construction Management Plan shall state whether any pile driving operation is intended and measures which will be taken to prevent noise and vibration detriment to any nearby sensitive receptor.

*Please confirm suitable means of communication of site operations which will be provided to neighbours
Reason: In order to safeguard the amenity

Lighting Plan: Lower level lighting, specified as 'Type 1' to be provided to areas proximal to sensitive receptors and to the north of the site in order to prevent detriment to the amenity of these properties and South Downs National Park.

Reason: In order to prevent detriment to the amenity