

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Sent: 25 November 2021 08:49
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Amy Myer <Amy.Myer@arun.gov.uk>
Subject: RE: Planning Consultation on: FG/184/21/PL

Engineers Comments Regarding Surface Water Drainage

Due to the scale, location and type of application we have no conditions to request. Any alterations to surface water drainage must be designed and constructed in accordance with Building Regulations.

It is noted that a Foul and Surface water Drainage Statement is supplied. The Building Inspector should note that the proposed design is based upon assumed infiltration rates. No groundwater monitoring or infiltration testing has been undertaken.

Kind regards

Sarah Burrow
Engineering Assistant, Engineering Services

T: 01903 737815
E: sarah.burrow@arun.gov.uk



Current working pattern: Monday-Wednesday 8am-2:30pm, Thursday 8am-5pm, Friday 8am-11:30am.

Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 18 October 2021 09:49
To: Land Drainage <Land.Drainage@arun.gov.uk>
Subject: Planning Consultation on: FG/184/21/PL

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: FG/184/21/PL
Registered: 15th October 2021
Site Address: 1 Greenways Crescent Ferring BN12 5EF
Grid Reference: 509577 102444
Description of Works: Erection of replacement dwelling and garage

The Council have received the above application.

[Click here to view the application details](#)

This application has been identified as CIL Liabe. Therefore please be aware that, in accordance with Appendix 2 of the Arun CIL Charging Schedule, your consultation response should only include requests for Section 106 for on site mitigation, Pagham Harbour Management Contributions (if applicable) or Affordable Housing. "Off" Site mitigation measures directly related to this development should be dealt with by condition if possible to ensure the scaling back of Section 106 if possible. CIL contributions will be used for "off" site infrastructure mitigation schemes. Therefore if this proposal triggers the need for "off" site mitigation, please ensure that you engage in the CIL Infrastructure List Consultation process upon receipt of a consultation letter.

Should you have any comments to make, these should be sent by replying to this email by 18th November 2021 . You can also monitor the progress of this application through the Council web site:

<https://www.arun.gov.uk/planning-application-search>

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website

<https://www.arun.gov.uk/development-plan> as can information on what comments we can consider
<https://www.arun.gov.uk/planning-application-comments>

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://app.planninginspectorate.gov.uk/> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Amy Myer

Planning Officer- Arun District Council

Telephone: 01903 737776

Email: amy.myer@arun.gov.uk

PLCONSULT (ODS) 2020