

[REDACTED]

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Sent: 21 January 2022 08:50
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: FG/184/21/PL

Engineers Comments Regarding Surface Water Drainage

Due to the scale, location and type of application we have no conditions to request. Any alterations to surface water drainage must be designed and constructed in accordance with Building Regulations.

The Building Inspector should be aware that the drainage design that has been supplied is based on an assumed infiltration rate with no on site infiltration testing completed.

Kind regards,

Sarah Burrow
Engineering Assistant, Engineering Services

T: 01903 737815
E: sarah.burrow@arun.gov.uk



Current working pattern: Monday-Wednesday 8am-2:30pm, Thursday 8am-5pm, Friday 8am-11:30am.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 17 December 2021 12:10

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Planning Consultation on: FG/184/21/PL

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: FG/184/21/PL
Registered: 15th October 2021
Site Address: 1 Greenways Crescent Ferring BN12 5EF
Grid Reference: 509577 102444
Category: Plan Applicat'n
Description of Works: Erection of replacement dwelling and garage

I am able to inform you that I have received an amendment to the above application dated 15th December 2021 relating to:- various revised plans.

[Click here to view the plans and documents](#)

If you should wish to make further representations as a result of this amendment you should click the link below and then click on 'Enter comment'.

[Click here to make further comments](#)

Please make any further comment by **21st January 2022**.

Please be aware that Planning Services operate an 'open file' policy and will publish your comments including your name and address on the website. We will aim to redact signatures, telephone numbers and email addresses but please help us by not incorporating them in the body of your text. Please make sure that you only include information that you are happy will be published in this way. If you supply information belonging to a third party, you must make sure you have their permission to do so.

Yours sincerely

Amy Myer

Planning Case Officer- Arun District Council

Telephone: 01903 737776

Email: amy.myer@arun.gov.uk

