

From: Laura Gibbons
Sent: 08 May 2018 09:54
To: Planning.Responses
Subject: RE: Please find attached amendment on planning application Ref: FG/206/17/PL

Engineers comments relating to surface water drainage

ENGD2A still applies.

The application proposes to attenuate surface water before discharging using an existing hydrobrake to control the volume discharged from the site. It is stated that infiltration is not suitable because of ground conditions, but no evidence of winter infiltration testing has been provided. This will need to be provided.

Calculations will need to be updated to include for +40% climate change.

I am pleased to see that the drainage from the hazardous zone is to go to foul sewer and not to surface water disposal. I agree with the plans in principle, if it can be proven that infiltration is not feasible. Further details will be required to discharge the condition.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 24 April 2018 15:20
To: Paul Cann
Subject: Please find attached amendment on planning application Ref: FG/206/17/PL

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION FG/206/17/PL

NO:

Registered:

24 JAN 18

Site Address: Land at Asda Superstore Littlehampton Road Ferring BN12 6PN

Grid Reference:

Category: Plan Applicat'n

Description of Works: Installation of a Six Pump (12 Filling Position) Petrol Filling station, Drive-to- Pay Kiosk & associated works including Jet Wash, Air/ Water Services & Vacuum Equipment

I am able to inform you that I have received an amendment to the above application dated 16th April 2018 relating to:- VARIOUS

[Click here to view the plans and documents](#)

If you should wish to make further representations as a result of this amendment you should click the link below and then click on 'comment on this application'. Please make any further comment by 1st March 2018.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

[Click here to make further comments](#)

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number Direct Dial: 01903 737529.

Thanking you in anticipation

Planning Case Officer

pmac21_email
