

From: Anita Gardner
Sent: 12 February 2015 15:36
To: [REDACTED]
Subject: FG/20/15/DOC - Balcony screening 9 Marine Drive, Ferring

Dear Mr Jones,

I refer to the above application. The details submitted are not acceptable. The balcony ends would need to be screened with 'obscure' glazing, not opaque and the screening would need to extend the depth of the balcony at a height of 1.8m as stated in the condition, not just a 0.3m depth.

Accordingly, I await confirmation of your clients intention's. Either the application can proceed to a decision and will be refused or substitute plans can be accepted provided they are received by the end of this month.

Yours sincerely

Anita Gardner

Anita Gardner | Principal Planner, Planning Department, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.