

[REDACTED]

[REDACTED]

[REDACTED]

From: Kevin Conlon [REDACTED]
Sent: 29 May 2019 09:42
To: Greenwood, Suz K
Cc: Anita Gardner
Subject: RE: Yeomans Honda - Ref: FG/40/19/DOC - Contamination

Good morning Suz,

Were you able to determine any feedback from your colleagues?

I hope we have now provided all the information needed to be able to discharge these conditions.

And, would very much appreciate your assistance in closing these out asap.

Kind regards,

Kevin

Kevin Conlon



HNW Architects Ltd. Registered office: 61 North Street, Chichester, West Sussex, PO19 1NB.
Registered in England no. 3589904

This e-mail is intended for the named addressee only. It contains information that may be confidential and which may also be privileged. Unless you are the named addressee you may neither copy nor use nor disclose it to anyone else. If you have received it in error please notify us immediately and destroy the e-mail. The copyright of all files attached to this e-mail remains the property of HNW Architects Ltd who grant license to approved parties to utilise the data solely in connection with the project for which it was prepared.

From: Greenwood, Suz K [REDACTED]
Sent: 15 May 2019 11:42
To: Kevin Conlon [REDACTED]
Subject: RE: Yeomans Honda - Ref: FG/40/19/DOC - Contamination

Morning.

Thank you for your email below. I am in meetings most of today and tomorrow so thought it would be easier to email you.

I will pass this information onto my groundwater colleagues and ask them to clarify the situation and what, if anything, is still needed.

I will get back to you asap.

Thanks

Suz

Suz Greenwood
Planning Advisor
Sustainable Places
Solent and South Downs

[REDACTED]

We offer a cost recovery service for bespoke pre-application advice. For more information go to: gov.uk or [email us](mailto:us)

From: Kevin Conlon [REDACTED]

Sent: 13 May 2019 16:56

To: Greenwood, Suz K [REDACTED]

Anita Gardner

<Anita.Gardner@arun.gov.uk>

Subject: RE: Yeomans Honda - Ref: FG/40/19/DOC - Contamination

Importance: High

Dear Miss Greenwood,

We are in receipt of your comments (attached) from Arun DC and wish to ask for some clarification on the points noted. I have left a message on your answerphone for you to call me back as I believe it'll be easier to talk these through, but understand you work Tuesdays to Thursdays.

To explain. Our new application (ref: FG/40/19DOC) for which we are seeking discharge of conditions 4 & 16 is associated with full planning application ref: FG/39/18/PL for which you note on your correspondence. I trust you are actually commenting on the information provided under application FG/40/19DOC rather than FG/39/18/PL. This DOC application was submitted to provide you with the information requested in your letter dated 6th March 19 ref: HA/2019/12136/01-L01 only. As a summary, you required further investigation to determine the extent of the impact in soils and ground water from hydrocarbon odours observed in one sampling well. This additional sampling/test results have been provided, and again attached for your information. Refer to attached GCC *Supplementary Soil & Groundwater Sampling* letter dated 2nd April. We understood that this was your sole comment in order to review the levels of contamination and subsequently allow discharge of conditions 4 & 16. And, then to highlight if a verification report is necessary. We are currently of the opinion that this is not required, due to the negligible levels of hydrocarbon odours remaining on-site.

Do we understand from the absence of any reference to this 'contamination' issue in this recent letter, that we have successfully demonstrated the negligible levels of hydrocarbon odours on site with this *Supplementary Sampling Report*? And, that your previous comments have been addressed and satisfied?

Therefore, we now wish to understand the comments made in your letter dated 25th April. Are these new comments in addition to those made in your letter dated 6th March?

Condition 4 – Do you require a copy of Southern Water's acceptance to our foul water connection proposal?

Condition 16 – An intrusive *Ground Conditions Assessment* (dated August 2018) was provided as part of application ref: FG/171/18DOC, for which you noted in your letter of 6th March the need for the above further hydrocarbon sampling. This assessment is again attached for your reference. We trust with the provision of this assessment and the *Supplementary Sampling Report* noted above, we now provide all information suitable enough to satisfy and discharge this condition.

I look forward to hearing from you at your earliest convenience to resolve these issues.

Kind regards,

Kevin

Kevin Conlon



HNW Architects Ltd. Registered office: 61 North Street, Chichester, West Sussex, PO19 1NB.
Registered in England no. 3589904

This e-mail is intended for the named addressee only. It contains information that may be confidential and which may also be privileged. Unless you are the named addressee you may neither copy nor use nor disclose it to anyone else. If you have received it in error please notify us immediately and destroy the e-mail. The copyright of all files attached to this e-mail remains the property of HNW Architects Ltd who grant license to approved parties to utilise the data solely in connection with the project for which it was prepared.

From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 13 May 2019 14:21
To: Kevin Conlon [REDACTED]
Subject: FW: Yeomans Honda - Ref: FG/40/19/DOC - Contamination

Dear Kevin,
Please see the attached response from Environment Agency. Do you have any additional information you can let me have to address their comments and prevent a refusal? If so can you let me have it by the end of the week?
Regards
Anita

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: PlanningSSD [REDACTED]
Sent: 13 May 2019 14:01
To: Anita Gardner
Subject: RE: Yeomans Honda - Ref: FG/40/19/DOC - Contamination

Dear Anita,

Thank you for your email below.
According to our records we replied to the 9/4/19 consultation on the 25/4/19. Please find attached a copy of our response.

Kind Regards,
Sustainable Places Team
Solent and South Downs Area
[REDACTED]

From: Anita Gardner [<mailto:Anita.Gardner@arun.gov.uk>]
Sent: 08 May 2019 09:34

To: PlanningSSD [REDACTED]

Subject: FW: Yeomans Honda - Ref: FG/40/19/DOC - Contamination

Hi ,
Please see e-mail below. The Environment Agency were consulted on this application on 09-04-2019 and a response is still awaited. Please can you let me have your comments ASAP and advise of the likely timescale by return.
Thanks
Anita

Anita Gardner | Principal Planner, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Kevin Conlon [REDACTED]

Sent: 08 May 2019 09:16

To: Anita Gardner

Cc: Steve Duffy; Antony Platt

Subject: RE: Yeomans Honda - Ref: FG/40/19 - Contamination

Good morning Anita,

Is there any word from the Environment Agency and/or Environmental Health, noting that their consultee response timescale has now elapsed?

We would be grateful if you could follow up, so we can close out these conditions asap.

Many thanks,

Kevin

Kevin Conlon



f in t @



HNW Architects Ltd. Registered office: 61 North Street, Chichester, West Sussex, PO19 1NB.
Registered in England no. 3589904

This e-mail is intended for the named addressee only. It contains information that may be confidential and which may also be privileged. Unless you are the named addressee you may neither copy nor use nor disclose it to anyone else. If you have received it in error please notify us immediately and destroy the e-mail. The copyright of all files attached to this e-mail remains the property of HNW Architects Ltd who grant license to approved parties to utilise the data solely in connection with the project for which it was prepared.

From: Kevin Conlon

Sent: 25 April 2019 11:08

To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Cc: Steve Duffy [REDACTED] Antony Platt [REDACTED]
Subject: RE: Yeomans Honda - Ref: FG/40/19 - Contamination

Dear Anita,

Noted, that makes their comments due back on Tuesday 30th April. We would truly appreciate your assistance in hastening back their comments on this date due to the sensitivity of this application.

The further information, i.e. additional sampling was at the request of the Environment Agency as they were *unable to recommend discharge of the application* until provided. And we were given no time to undertake and submit these within our original application ref: FG/171/18/DOC before refusal. These test sample results are now provided, so we would believe it to be a very quick exercise for the EA to review and okay discharge.

Kind regards,

Kevin

Kevin Conlon



HNW Architects Ltd. Registered office: 61 North Street, Chichester, West Sussex, PO19 1NB.
Registered in England no. 3589904

This e-mail is intended for the named addressee only. It contains information that may be confidential and which may also be privileged. Unless you are the named addressee you may neither copy nor use nor disclose it to anyone else. If you have received it in error please notify us immediately and destroy the e-mail. The copyright of all files attached to this e-mail remains the property of HNW Architects Ltd who grant license to approved parties to utilise the data solely in connection with the project for which it was prepared.

From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 23 April 2019 17:41
To: Kevin Conlon [REDACTED]
Subject: RE: Yeomans Honda - Ref: FG/40/19 - Contamination

Dear Kevin,

The consultations to Environment Agency and Environmental Health were sent on 09-04-2019 and consultees have a target response time of up to 21 days so I don't anticipate a reply until the end of the month.

Regards

Anita Gardner

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Kevin Conlon [REDACTED]
Sent: 23 April 2019 14:30
To: Anita Gardner
Subject: Yeomans Honda - Ref: FG/40/19 - Contamination
Importance: High

Dear Anita,

Would you please be able to chase up the EA with our submission for conditions 4 & 16?

Many thanks in anticipation of resolving these two conditions.

Kevin

Kevin Conlon



HNW Architects Ltd. Registered office: 61 North Street, Chichester, West Sussex, PO19 1NB.
Registered in England no. 3589904

This e-mail is intended for the named addressee only. It contains information that may be confidential and which may also be privileged. Unless you are the named addressee you may neither copy nor use nor disclose it to anyone else. If you have received it in error please notify us immediately and destroy the e-mail. The copyright of all files attached to this e-mail remains the property of HNW Architects Ltd who grant license to approved parties to utilise the data solely in connection with the project for which it was prepared.

From: Kevin Conlon
Sent: 17 April 2019 16:58
To: 'Anita Gardner' <Anita.Gardner@arun.gov.uk>
Subject: RE: Yeomans Honda - Ref: FG/39/18 Discharge of Condition 3 Surface Water Drainage

Dear Anita,

Discharge notice for Condition 3 received this afternoon with thanks.

Is there any progress on 4 & 16 (contamination) with the EA?

Kind regards,

Kevin

From: Kevin Conlon
Sent: 17 April 2019 09:10
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: RE: Yeomans Honda - Ref: FG/39/18 Discharge of Condition 3 Surface Water Drainage

Dear Anita,

Now that we have Laura's approval, do you know when we can expect full Discharge of this Condition?

Kind regards,

Kevin

From: Anita Gardner <Anita.Gardner@arun.gov.uk>

Sent: 12 April 2019 12:37

To: Kevin Conlon [REDACTED]

Subject: RE: Yeomans Honda - Ref: FG/39/18 Discharge of Condition 3 Surface Water Drainage

Dear Kevin,

I will process these additional and substitute details against reference FG/32/19/DOC whilst I await Laura's comments

Regards

Anita

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Kevin Conlon [REDACTED]

Sent: 12 April 2019 09:52

To: Laura Gibbons; Anita Gardner

Cc: Russell Scorey; Noelia Jara Galvez; Steve Duffy; Ali Riza Yozdhanla

Subject: RE: Yeomans Honda - Ref: FG/39/18 Discharge of Condition 3 Surface Water Drainage

Importance: High

Dear Laura,

Apologies for the slight delay in replying. We have been collating a suitable response and updated drawings and details to hopefully address your queries.

We are pleased to forward the revised drainage plan and exceedance routes plan with external levels shown as per your request. Please see also enclosed build-up detail for the permeable paving.

With regard to the soakaway, we can forward the intended manufacturer's detail for your reference.

Please see below our Civil Engineer's responses to your comments:

1. 480mm is total thickness of permeable paving. However, it has been modelled with 300mm sub-base thickness, please refer to value 'Cap Volume Depth = 0.300m'. With this value the program takes into account the thickness of the sub-base as the only storage available.
2. Please find enclosed standard construction details of the intended Tubosider product.
3. Exceedance flow routes plan has been provided for storms greater than 1 in 100 + 40% cc critical storm. No flooding will occur off site for events up to and including the 1 in 100 year plus cc as stated in the report. Please refer to calculations, no flooding occurs during this event. Exceedance plan (YEO-AKSW-XX-GF-DR-C-9205-P03) has been updated to incorporate proposed external levels for your reference.
4. Please find attached drainage plan (YEO-AKSW-XX-GF-DR-C-9201-C06) which has been updated to incorporate external levels and formation level for car park.
5. Please see build-up drawing attached (YEO-AKSW-XX-XX-DR-C-9501-C01)


We trust this now concludes all outstanding information and clarifications of detail for this condition to now be discharged at your earliest convenience.

Many thanks for your assistance in this regard.

Kevin

Kevin Conlon

f in @

A banner for HNW Architects. On the left is the 'ROUGH RUNNER' logo featuring stylized figures. In the center is a photograph of a group of people running on a path. On the right is the 'Dementia SUPPORT' logo, which includes a stylized flower icon. The text on the banner reads: 'HNW architects', 'HNW are taking part in the Rough Runner Challenge on the 13th April to raise money and support for local charity 'Dementia Support'. Please support us and them by clicking the image below;'.

HNW architects

HNW are taking part in the **Rough Runner Challenge** on the **13th April** to raise money and support for local charity '**Dementia Support**'.
Please support us and them by clicking the image below;

ROUGH RUNNER

Dementia SUPPORT

HNW Architects Ltd. Registered office: 61 North Street, Chichester, West Sussex, PO19 1NB.
Registered in England no. 3589904

This e-mail is intended for the named addressee only. It contains information that may be confidential and which may also be privileged. Unless you are the named addressee you may neither copy nor use nor disclose it to anyone else. If you have received it in error please notify us immediately and destroy the e-mail. The copyright of all files attached to this e-mail remains the property of HNW Architects Ltd who grant license to approved parties to utilise the data solely in connection with the project for which it was prepared.

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>

Sent: 08 April 2019 11:12

To: Kevin Conlon [REDACTED] Anita Gardner <Anita.Gardner@arun.gov.uk>

Subject: RE: Yeomans Honda - Ref: FG/39/18 Discharge of Condition 3 Surface Water Drainage

Kevin,

Thank you for providing the updated proposals. I have reviewed these and have the following comments:

1. I note that the proposed layout drawing states that permeable paving will have 300mm sub-base thickness, yet 480mm has been modelled. Details must be consistent.
2. The construction detail drawings of the infiltration system are not correct and seem to refer to the previously proposed attenuation system. Please can these details be updated.

3. Exceedance flow routes have been provided along with a statement that no flooding will occur off site for events up to and including the 1 in 100 year plus cc event yet these statements have not been quantified. Please can proposed finish levels be provided, along with any kerb levels.
4. Please provide formation levels of the permeable paving on plan.
5. Please provide construction detail drawings of permeable paving.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Kevin Conlon [REDACTED]
Sent: 04 April 2019 15:41
To: Anita Gardner; Laura Gibbons
Cc: Russell Scorey; Noelia Jara Galvez; Steve Duffy
Subject: RE: Yeomans Honda - Ref: FG/39/18 Discharge of Condition 3 Surface Water Drainage
Importance: High

Dear Anita,

Further to recent communications our Civil Engineer has had with Ms Laura Gibbons, and their agreement to move forward with a shallow infiltration solution, we are pleased to forward the revised Drainage Strategy and Layout Plan to substitute those previously issued.

As discussed, the revised solution is to implement a scheme of shallow infiltration perforated pipes across the car parking site area to suit the recorded ground water levels. The levels are recorded in the attached drainage strategy.

We trust this revised solution now suitably addresses Arun DC's policy requirements, and therefore can allow this condition to be discharged in full at your earliest convenience.

Kind regards,

Kevin

Kevin Conlon



This e-mail is intended for the named addressee only. It contains information that may be confidential and which may also be privileged. Unless you are the named addressee you may neither copy nor use nor disclose it to anyone else. If you have received it in error please notify us immediately and destroy the e-mail. The copyright of all files attached to this e-mail remains the property of HNW Architects Ltd who grant license to approved parties to utilise the data solely in connection with the project for which it was prepared.

From: Kevin Conlon
Sent: 19 March 2019 10:28
To: Anita Gardner <Anita.Gardner@arun.gov.uk>

Subject: Yeomans Honda - Ref: FG/39/18 Discharge of Condition 3 Surface Water Drainage
Importance: High

Dear Anita,

We have today lodged a fresh application onto the Planning Portal reference: **PP-07714252** to discharge Condition 3, associated with Arun DC planning reference: FG/39/18.

The attached information has been uploaded to the Portal, and also recently copied across to Laura Gibbons by the Civil Engineer (AKS Ward) whom awaits her comments/approval.

You'll note the revised plans now illustrate a scheme of attenuation tanks to hold then drain to the main SW sewers rather than previously designed infiltration crates. This is due to the newly recorded winter ground water levels, and the encroachment into the 'buffer' zone below the bottom of the infiltration crates, which we understand is against Arun Policy. We trust Arun DC now find these proposals acceptable as all monitoring has been carried out, assessed and addressed in accordance with current policy.

As previously discussed, we would be extremely grateful if this application can be registered and addressed for approval with Arun's Flood Engineers asap.

Kind regards,

Kevin

Kevin Conlon
Senior Architect

The logo for HNW Architects, featuring the lowercase letters 'hnw' in a bold, sans-serif font, followed by the word 'architects' in a smaller, lowercase, sans-serif font. The logo is set against a dark, textured background.

<http://www.arun.gov.uk>
DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>
DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>
DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>
DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

This message has been scanned and no issues were discovered.
[Click here](#) to report this email as spam

Information in this message may be confidential and may be legally privileged. If you have received this message by mistake, please notify the sender immediately, delete it and do not copy it to anyone else.

We have checked this email and its attachments for viruses. But you should still check any attachment before opening it.

We may have to make this message and any reply to it public if asked to under the Freedom of Information Act, Data Protection Act or for litigation. Email messages and attachments sent to or from any Environment Agency address may also be accessed by someone other than the sender or recipient, for business purposes.

[Click here](#) to report this email as spam

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

This message has been scanned and no issues were discovered.
Click [here](#) to report this email as spam

Information in this message may be confidential and may be legally privileged. If you have received this message by mistake, please notify the sender immediately, delete it and do not copy it to anyone else.

We have checked this email and its attachments for viruses. But you should still check any attachment before opening it.

We may have to make this message and any reply to it public if asked to under the Freedom of Information Act, Data Protection Act or for litigation. Email messages and attachments sent to or from any Environment Agency address may also be accessed by someone other than the sender or recipient, for business purposes.

Click [here](#) to report this email as spam