

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>

Sent: 20 November 2019 15:47

To: Planning.Responses <Planning.Responses@arun.gov.uk>; Land Drainage <Land.Drainage@arun.gov.uk>

Cc: Andrew Wood <Andrew.Wood@arun.gov.uk>; Paul Cann <Paul.Cann@arun.gov.uk>

Subject: RE: Planning Consultation on: FG/141/19/PL

Engineers Comments Regarding Surface Water Drainage

On the basis of the known surface water drainage network in the vicinity of the proposed development, there are concerns that there may be an unmapped pipe leading to the pond, located under the garden to the north of the proposed building. It is not permitted to restrict current and future land owners from undertaking their riparian maintenance responsibilities in respect to any watercourse or culvert on or adjacent to the site as a result of construction activities. The local byelaws require a 3m easement from any watercourse be it open or piped.

If you are minded to approve the application please apply the following conditions to ensure that the development is adequately drained and does not increase flood risk elsewhere. If these conditions are applied, the applicant is encouraged to liaise with the engineering department to organise conducting intrusive investigations into the location of the suspected culvert in order to discharge condition PCENG D3.

PCENG D2

"Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity."

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

PCENG D3

"The development shall not proceed until details have been submitted to and approved in writing by the Local Planning Authority for any proposals: to discharge flows to watercourses; or for the culverting, diversion, infilling or obstruction of any watercourse on or adjacent to the site. Any discharge to a watercourse must be at a rate no greater than the pre-development run-off values. No construction is permitted, which will restrict current and future land owners from undertaking their riparian maintenance responsibilities in respect to any watercourse or culvert on or adjacent to the site. "

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. And to ensure that the duties and responsibilities, as required under the

Land Drainage Act 1991, and amended by the Flood and Water Management Act 2010, can be fulfilled without additional impediment following the development completion. It is considered necessary for this to be a pre-commencement condition to protect existing watercourses prior to the construction commencing.

And the following informative:

INFORMD

"Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers. Supplementary guidance notes regarding surface water drainage are located here <https://www.arun.gov.uk/surfacewater> on Arun District Councils website. A surface water drainage checklist is available here <https://www.arun.gov.uk/drainagechecklist> on Arun District Councils website, this should be submitted with a Discharge of Conditions Application."

INFORMD2

"Under Section 23 of the Land Drainage Act 1991 Land Drainage Consent must be sought from the Lead Local Flood Authority (West Sussex County Council), or its agent (Arun District Council land.drainage@arun.gov.uk), prior to starting any works (temporary or permanent) that affect the flow of water in an ordinary watercourse. Such works may include culverting, channel diversion, discharge of flows, connections, headwalls and the installation of trash screens.

The development layout must take account of any existing watercourses (open or culverted) to ensure that future access for maintenance is not restricted. No development is permitted within 3m of the bank of an ordinary watercourse, or 3m of a culverted ordinary watercourse."

From: planning.responses@arun.gov.uk <planning.responses@arun.gov.uk>

Sent: 15 November 2019 15:34

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Planning Consultation on: FG/141/19/PL

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

APPLICATION NO: FG/141/19/PL

Registered: 15th November
2019

Site Address: Elm Lodge Tamarisk Way Ferring BN12 5ER

Grid Reference: 509834 102037

Description of Works:

Erection of 1 No detached chalet style dwelling with integral garage;
demolition of existing conservatory & porches & erection of single
storey side extension & part single/part two storey side extension to
Elm Lodge (resubmission of FG/220/18/PL).

The Council have received the above application. I shall be pleased to receive any
observations you may wish to make.

[Click here to view the application details](#)

**Should you have any comments to make, these should be sent by replying to this email
by 19-DEC-19.**

You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

**Please be aware that any comments you may make will be available on our website so
please do not insert personal details or signatures on your reply.**

In the absence of a reply within the period stated, I shall assume that you have no observations
to make.

The application will be determined having regard to the development plan policies (if any are
relevant) and other material considerations. The development plan can be accessed via the
website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments
made to the Council on their website: www.planningportal.gov.uk/planning/appeals/ but they
will protect personal details.

The officer dealing with this application is Andrew Wood who can be contacted on telephone
number 01903 737768.

Regards
Planning Officer

consultee_email
