

From: Amanda Scholes on behalf of Planning.Responses
Sent: 26 June 2019 09:23
To: Planning Scanning
Subject: FW: Planning Consultation on: FG/46/19/PL

From: Laura Gibbons
Sent: 26 June 2019 08:03
To: Planning.Responses
Cc: Zac Denton
Subject: RE: Planning Consultation on: FG/46/19/PL

Engineers comments regarding surface water drainage

The grid and materials that are proposed to be used to form the parking surface would form a permeable surface. As a result the proposals would not increase runoff, and would as closely as possible reflect what was there previously. We therefore have no conditions to request.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses
Sent: 25 June 2019 13:53
To: Land Drainage
Subject: Planning Consultation on: FG/46/19/PL

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure)
(England) Order 2015
Planning Permission
APPLICATION FG/46/19/PL
NO:
Registered: 2nd May

2019
Site Address: East Of The Bluebird Cafe South Drive Ferring
BN12 5QU
Grid Reference: 509153 101498
Description of Works: Refurbishment of existing car park. Providing a permeable SuDS ground reinforcement grid paving system. Providing a level allocated car parking spaces.

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 07-JUN-19.

You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Zac Denton who can be contacted on telephone number [REDACTED]

Regards
Planning Officer

consultee_email
