



from

**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
FG/74/20/DOC

Our ref
PLAN-033750

Date
07/07/2020

Contact

Dear Sir/Madam,

Proposal: Approval of details reserved by condition imposed under ref FG/152/19/PL relating to Condition Nos 3 - surface water drainage, 4 - bat survey, 9 - landscaping to North & West boundaries and 14 - Construction Management Plan.

Site: FG/74/20/DOC: - 40, Little Paddocks, Ferring, BN12 5NJ.

Thank you for your letter dated 23/06/2020.

Southern Water would not recommend discharge of condition 03 regarding surface water drainage.

No drainage layout relating to surface water disposal is available. The applicant shall submit a detailed drainage layout plan clearly indicating the on-site drainage and their relevant discharge points.

Southern Water have no comments to make with regards to other conditions.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (T:)

Yours faithfully,

Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670