

[REDACTED]

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>

Sent: 06 August 2020 10:27

[REDACTED]

Subject: RE: FG/74/20/DOC - 40 Little Paddocks - discharge of conditions application

Good morning Zac/Joe,

I have gone through the relevant documents and whilst the majority is fine, Paul Cann (Principle Engineer) is asking me to push back on the perforated pipe arrangement that was discussed with the engineer to reduce the likelihood of blockage. Once this has been included on the layout and construction details I will be happy to recommend discharge of conditions. I am also happy to reduce my consultation period to ensure that Zac can meet his determination deadline, with the knowledge that the Engineer had been awaiting further information from us which was delayed (causing the omission in the submission).

Kind Regards

Sarah Burrow

Engineering Assistant, Engineers

Current Working Hours:

Monday-Wednesday, Friday: 8:00 – 17:00

Thursday 8:00 – 11:00

Some of this time is spent on site.

T: 01903 737815

E: sarah.burrow@arun.gov.uk

[REDACTED]



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

From: Joe Treherne [REDACTED]

Sent: 03 August 2020 09:34

[REDACTED]

Subject: FG/74/20/DOC - 40 Little Paddocks - discharge of conditions application

Dear Zac,

Further to our conversation on Friday, please find attached approval letter from Southern Water, together with the proposed drainage layout and calculations from the drainage engineer, to satisfy condition 3.

We trust that the above and attached are satisfactory and that this condition can now be discharged, together with conditions 4, 9 & 14.

Kind regards

Joe

Joe Treherne BArch (Hons), MArch, DipArch, RIBA

Architect



Robert Shreeve Associates Ltd.

Office: 1 Stable Offices, Furnace Farm, Furnace Lane, Lamberhurst,
Tunbridge Wells, Kent TN3 8LE

Registered office: Grosvenor Lodge, 72 Grosvenor Road, Tunbridge Wells,
Kent TN1 2AZ Registered no. 5358702 V.A.T. Number 445 757812

[REDACTED]



This information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful.

Robert Shreeve Associates have taken reasonable precautions to ensure no viruses are present in this email and cannot accept responsibility for any loss or damage arising from the use of this email or attachments.

Our GDPR Statement can be found [here](#).

