




From: Carol Reynolds
Sent: 06 September 2019 08:18
To: Zac Denton <Zac.Denton@arun.gov.uk>
Subject: RE: FG/78/19/DOC Yeomans Ltd., Littlehampton Road, Ferring, BN12 6PB

Environmental Health: I refer to the Acoustic Report prepared by Peter Clark of PC Environmental Ltd, dated 9th July 2019, Reference 12370. There is an error to paragraph 3.3 of page 6 which should read 'The night time noise levels are reduced to 13dB(A) and **32** not 41dB(A) respectively...' Otherwise I have no objection to the findings of this report and agree discharge of Condition 13 in respect of Planning Application FG/78 /19/DOC accordingly.

From: Zac Denton
Sent: 05 September 2019 14:05
To: Carol Reynolds <Carol.Reynolds@arun.gov.uk>
Subject: RE: FG/78/19/DOC

As requested.

Thanks,

Zac

Zachariah Denton | Planning Officer, Planning Department, Directorate of Place, Arun District Council | Location: First Floor , Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37447 | External: +44 (0) 1903 737500 Ext: 37447 | E-mail: zac.denton@arun.gov.uk

Please note this information is given without prejudice and represents the informal view of the officer and not an official opinion of Arun District Council.