

Daun Johnson

To: [REDACTED]
Subject: RE: FG/86/15/HH

Mr Barratt,

It is relevant so we know that the windows are not changing. If it is not the same between the floor plans and elevations, we do not know which one is correct.

Thank you,
Mrs Johnson

Daun Johnson | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37762 | External: +44 (0) 1903 737762 | E-mail: daun.johnson@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 11 June 2015 17:40
To: Daun Johnson
Subject: Re: FG/86/15/HH

Thank you for email. Is this relevant as these windows are not being altered?

Sent from my iPhone

On 11 Jun 2015, at 14:32, Daun Johnson <Daun.Johnson@arun.gov.uk> wrote:

Mr Barratt,

Thank you for the photos. It is clear now, however, you will still need to show the detail of the framework on the North and South elevations.

I have added the photos to the file.

Thank you,
Mrs Johnson

Daun Johnson | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37762 | External: +44 (0) 1903 737762 | E-mail: daun.johnson@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Steven Barrett [REDACTED]
Sent: 11 June 2015 01:33

To: Daun Johnson
Subject: FG/86/15/HH

Dear Mrs Johnson.

Thank you for your email. Please find attached the photos that were sent to you on the 1st June. As already discussed the windows on plan are individual windows however, due to the UPVC cover strip over the walls dividing the rooms which form part of the window frame, on elevation this makes it appear a continuous window.

I hope this clarifies the situation.

Kind regards

Steve Barrett

***** IMPORTANT NOTICE: This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

***** <http://www.arun.gov.uk> : NLPG UPRN 100062237016 : DX 57406

Littlehampton <http://www.arun.gov.uk>

NLPG UPRN 100062237016

DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

Daun Johnson

To: Steven Barrett
Subject: RE: FG/86/15/HH

Mr Barratt,

Thank you for the photos. It is clear now, however, you will still need to show the detail of the framework on the North and South elevations.

I have added the photos to the file.

Thank you,
Mrs Johnson

Daun Johnson | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37762 | External: +44 (0) 1903 737762 | E-mail: daun.johnson@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Steven Barrett [REDACTED]
Sent: 11 June 2015 01:33
To: Daun Johnson
Subject: FG/86/15/HH

Dear Mrs Johnson.

Thank you for your email. Please find attached the photos that were sent to you on the 1st June. As already discussed the windows on plan are individual windows however, due to the UPVC cover strip over the walls dividing the rooms which form part of the window frame, on elevation this makes it appear a continuous window.

I hope this clarifies the situation.

Kind regards

Steve Barrett

Daun Johnson

To: Steven Barrett [REDACTED]
Subject: FW: Further Information Required on Your Ref: N/A Our Ref: FG/86/15/HH

Mr Barrett,

Thank you for the updated proposed ground floor and roof plan, which was received in this office on 10th June 2015.

Unfortunately, I have not received any photos that you said you have sent. Please email the photos to me directly.

I have spoken to my team leader about the plans and she has confirmed that the North and South elevations and floor plans are still not clear. The south floor shows three separate windows while the elevation only shows two separate windows. The north elevation shows three windows while the floor plans show one large window. If you could show the framework on these windows, perhaps it would be clearer.

If you have any questions, please let me know.

Thank you,
Mrs Johnson

Daun Johnson | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37762 | External: +44 (0) 1903 737762 | E-mail: daun.johnson@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Daun Johnson
Sent: 01 June 2015 09:47
To: 'Steven Barrett'
Subject: RE: Further Information Required on Your Ref: N/A Our Ref: FG/86/15/HH

Mr Barrett,

Thank you for your email.

I did not say that the floor plans or elevations were not labelled correctly. I said that 'the existing and proposed north, south and west floor plans and elevations do not accord. Please amend accordingly'.

If you look on the existing ground floor plan, the bathroom window (north) does not scale (accord) with the window on the elevation. The dining room window (west) is not shown on the floor plan. The two bedroom windows (south) show two separate windows while the elevation shows one window.

The proposed ground floor plan bathroom window (north) does not scale (accord) with the window on the elevation. The study window (w) is not shown on the floor plan. The sunroom and bedroom (south) shows two separate windows while the elevation shows one window.

If you have any questions, please let me know.

Thank you,
Mrs Johnson

Daun Johnson | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37762 | External: +44 (0) 1903 737762 | E-mail: daun.johnson@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Steven Barrett
Sent: 31 May 2015 20:23
To: Planning.Responses
Subject: Re: Further Information Required on Your Ref: N/A Our Ref: FG/86/15/HH

Dear Mrs Johnson

RE FG/86/15/HH

Thank you for your letter. I am unsure what elevations you think I have labelled incorrectly.

The North point on the existing and proposed plans is correct which indicates the front elevation as being West, rear elevation as East, elevation with the garage is North. Therefore, the elevations and plans accord.

Kind regards

Steven Barrett

On Friday, 29 May 2015, 16:18, "planning.responses@arun.gov.uk" <planning.responses@arun.gov.uk> wrote:

***** IMPORTANT NOTICE: This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments. ***** <http://www.arun.gov.uk> : NLPG UPRN 100062237016 : DX 57406 Littlehampton <http://www.arun.gov.uk>

NLPG UPRN 100062237016

DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

Daun Johnson

To: Steven Barrett
Subject: RE: Further Information Required on Your Ref: N/A Our Ref: FG/86/15/HH

Mr Barrett,

Thank you for your email.

I did not say that the floor plans or elevations were not labelled correctly. I said that 'the existing and proposed north, south and west floor plans and elevations do not accord. Please amend accordingly'.

If you look on the existing ground floor plan, the bathroom window (north) does not scale (accord) with the window on the elevation. The dining room window (west) is not shown on the floor plan. The two bedroom windows (south) show two separate windows while the elevation shows one window.

The proposed ground floor plan bathroom window (north) does not scale (accord) with the window on the elevation. The study window (w) is not shown on the floor plan. The sunroom and bedroom (south) shows two separate windows while the elevation shows one window.

If you have any questions, please let me know.

Thank you,
Mrs Johnson

Daun Johnson | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37762 | External: +44 (0) 1903 737762 | E-mail: daun.johnson@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Steven Barrett
Sent: 31 May 2015 20:23
To: Planning.Responses
Subject: Re: Further Information Required on Your Ref: N/A Our Ref: FG/86/15/HH

Dear Mrs Johnson

RE FG/86/15/HH

Thank you for your letter. I am unsure what elevations you think I have labelled incorrectly.

The North point on the existing and proposed plans is correct which indicates the front elevation as being West, rear elevation as East, elevation with the garage is North. Therefore, the elevations and plans accord.

Kind regards

Steven Barrett

On Friday, 29 May 2015, 16:18, "planning.responses@arun.gov.uk" <planning.responses@arun.gov.uk> wrote:

***** IMPORTANT NOTICE: This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments. ***** <http://www.arun.gov.uk> : NLPG UPRN 100062237016 : DX 57406 Littlehampton <http://www.arun.gov.uk>

NLPG UPRN 100062237016

DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
