

[REDACTED]

Please upload the email below from Environmental Health onto Ocella for FP/103/19/PL.

Thanks,

Michael

[REDACTED]

Arun is a CIL Charging Authority, for more information go to [www.arun.gov.uk/cil/](http://www.arun.gov.uk/cil/)

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.

[REDACTED]

Dear Michael,

Environmental Health has no objections in principle to this application.

However, I note in the detailed Hard and Soft Landscape General Arrangement Plan (Sheet 1 of 2) plan dwg. D1530 .320 that Boundary Type 1 is 'Acoustic Fence. Product: height, colour, fixtures and fittings are to specialist's specifications'. Please could the applicant expand on this to give specific details about the acoustic fence. This is in part due to the fact that the acoustic fence further to the south of this development was built with a gap between the bottom of the fence and the top of the soil bund, which would have impacted on the effectiveness of the fence, and I would like to avoid the possibility of this happening again.

Regards

Fiona

[REDACTED]

[Redacted]

Hi Fiona,

Please could I have your consultation response to planning application **FP/103/19/PL**: Amendment to Planning Reference Y/68/09 to replace sports pitch with a public amenity area on land at Blakes Mead (Site 6: Felpham) north of Felpham by **5.00pm** on **Friday 17<sup>th</sup> April 2020**.

Kind regards,

Michael

M: [Redacted]

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.