



Good morning Simon, hope you're well.

In relation to condition 22 as well as streetlights on this development there are also small fixed external lights to the front of each property which were not included on the SSE layout as they are PIR installations on buildings. I have shown approximate locations of these on the plan attached so all lighting is included, I don't know the light spill of these but they are more for part Q/SBD safety PIR lighting so are only on when activated as opposed to permanent luminance.

With regards to the street lighting columns there are 5 unmetered supplies on site. 6m in height as per the spec submitted alongside layout. Columns numbered 3-7 are the ones inside the development, columns 1-2 are outside the redline boundary. Tilt of heads etc is shown also within the luminance report.



With regards to light spillage this is shown on the layout submitted and shows where the coverage of the road in terms of what it illuminates. There is limited light spill to the boundaries where existing trees are, this can be shown by the smaller black numbers decreasing, the lighting design and the columns locations were designed for the safety of drivers, and the respect of habitable dwellings (not outside bedroom windows etc) but also not pose to much of a risk to birds etc.






I hope this clarifies the queries below.

Kind regards

Grace Palmer
Technical Manager

Hampshire Homes Group

8 Chatmohr Estate | Crawley Hill | Nr Romsey | Hampshire | SO51 6AP



Dear Grace,

I have had Environmental Health comments regarding the lighting. The Officer asks that you clarify the number and position of units (to include streetlighting and any installations on buildings) as they don't consider this to be entirely clear from the submission. EH just need to be sure that the installations are not likely to create overspill/glare/creep/bleed etc. Please can you provide

clarification.

Thanks.

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil
Sign up to our newsletter [here](#)

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
