

hda

projects

6 The Old Flour Mill

Queen Street

Emsworth

Hants

PO10 7BT

Our Ref: 1430/wtm

5 August 2015

Planning & Economic Regeneration
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Dear Sir

**FP 152 14 PL: Semi Detached three bedroom chalet houses at 114 Felpham Way,
Bognor Regis PO22 8QW**

Further to your request our clients have provided the following reports

Soakage Test: 500 x 500 x 1.2 deep trial pit excavated October 2014, the pit was filled with water
outflow timed at 45 minutes to drain between 75% and 25%.

The resulting soil infiltration rate = 0.0033m/s

The pit was monitored monthly through to March 2015 and was dry on all occasions.

Soakaway calculations for 10 + 30 year +30% as attached.

Please contact us should you require further information.

Yours sincerely

Will Matthews

William T Matthews
Hda projects

Director: · William Matthews ·

hda projects Limited · Company Registration No. 6216888 · Registered in England

Architectural Services and Building Design Consultants