

[REDACTED]

[REDACTED]

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



[REDACTED]

From: Ian Stocks [REDACTED] On Behalf Of FRS Water and Access
Sent: 31 August 2021 07:10
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: FP/170/21/PL – Emergency Access Gates, Blake’s Mead, Felpham

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Dear Michael,

As the gates have now replaced the drop bollards and secured with a combination padlock, West Sussex Fire & Rescue Service would have no objection to the retention of guard rails (chicane) in place of bollards, and the retention of the 1.2 metre high post and rail fencing adjacent to the emergency access gate.

If emergency access is required padlocks can be cropped off to enable the gats to be opened.

Regards

Ian Stocks

Ian Stocks – Water and Access Manager
Water and Access Office
West Sussex Fire and Rescue Service West Sussex County Council

Living Our Values Every Day

