

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Simon Davis

Sent: 08 October 2018 13:10

To: [REDACTED]

Subject: RE: Letter to Parish Council Re Drainage queries. FP/171/18/PL

Dear Pete,

I have had drainage advice re the recent drainage documents. The advice is:

"The letter provided has a mistake within it. All discharge rates should be stated as 2.8l/s. Within the cellular attenuation crates section "5 l/s" is stated. This needs to be corrected, so that no contradictory details are present. 2.8l/s is the correct figure."

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.