

From: Simon Davis
Sent: 08 October 2018 13:08
To: Planning.Responses
Subject: FW: Application FP/171/18/PL

Further Drainage Engineer comments.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 08 October 2018 12:51
To: Simon Davis
Subject: RE: Application FP/171/18/PL

Hi Simon,

The letter provided has a mistake within it. All discharge rates should be stated as 2.8l/s. Within the cellular attenuation crates section "5 l/s" is stated. This needs to be corrected, so that no contradictory details are present. 2.8l/s is the correct figure.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltrovers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 02 October 2018 10:42

To: Laura Gibbons
Subject: FW: Application FP/171/18/PL

FYI. Please provide further comment.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maitravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 02 October 2018 07:34
To: Simon Davis
Subject: Application FP/171/18/PL

Hi Simon,

Please find the attached, revised, drainage plan and Drainage Statement to supersede those you have already and take into account the comments received by Laura Gibbons who has agreed that the drainage scheme is acceptable in principle.

With regard to the concerns raised by the Parish, I will send a separate cover on this later today.

Kind regards,

Pete

Planning Dept.

James Potter Associates Ltd
Architectural design

