

[REDACTED]

From: Amanda Scholes on behalf of Planning.Responses
Sent: 11 October 2018 10:05
To: Planning Scanning
Subject: FW: Letter to Parish Council Re Drainage queries. FP/171/18/PL

From: Simon Davis
Sent: 10 October 2018 13:15
To: Planning.Responses
Subject: FW: Letter to Parish Council Re Drainage queries. FP/171/18/PL

[REDACTED]

From: Laura Gibbons
Sent: 10 October 2018 10:49
To: Simon Davis
Subject: RE: Letter to Parish Council Re Drainage queries. FP/171/18/PL

Hi Simon,

Based on the supplied information I am happy with the broad drainage proposals and will review them in full detail at DOC stage. I believe I have requested ENGD2B, ENGD3A, ENGD4A, ENGD5A, ENGD5B and ENGD6A.

ENGD2B can be adapted to now remove the requirement for winter infiltration testing, infiltration didn't work in the summer, so it isn't going to work in the winter.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

[Laura Gibbons](#) | Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

[REDACTED]

Arun is Working in Partnership with Chichester District Council

[REDACTED]



Save the environment - think before you print.

From: Simon Davis
Sent: 09 October 2018 10:11
To: Laura Gibbons
Subject: FW: Letter to Parish Council Re Drainage queries. FP/171/18/PL

Hi Laura,

Amended Drainage Statement following your comment.

Kind Regards

Simon J. Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.