




From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 30 October 2020 13:30
To: Amber Willard <Amber.Willard@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FP/189/20/PL - land between 49 and 51 Summerley Lane, Felpham, PO22 7LF

Dear Amber,

In relation to the above application, please may EH comment as follows:

- No demolition/construction activities shall take place, other than between 08:00 to 18:00 hours (Monday to Friday) and 08:00 to 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays. **Reason:** To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031
- No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved plan shall be implemented and adhered to throughout the entire construction period. The plan shall provide details as appropriate but not necessarily be restricted to the following matters:
 - a) An indicative programme for carrying out of the works;
 - b) Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
 - c) Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);

- d) Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
- e) The parking of vehicles of site operatives and visitors;
- f) Loading and unloading of plant and materials, including permitted times for deliveries;
- g) Storage of plant and materials used in constructing the development;
- h) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- i) The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
- j) Measures to control the emission of dust and dirt during construction;
- k) A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

- No external lighting shall be installed until details have been submitted to and approved in writing by the Local Planning Authority prior to commencement of the development. This submission shall include a layout plan with beam orientation and a schedule of light equipment proposed (luminaire type, mounting height, aiming angles and luminaire profiles). The approved scheme shall be installed, fully assessed by a competent individual when operational to ensure no light creep/bleed, maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to a variation.

Reason: To protect the appearance of the area/the environment and wildlife/local residents from pollution.

- Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM1 of the adopted Arun Local Plan 2011 – 2031.
- The owner(s) of any commercial property (warehouses, offices, etc.) built before 2000 are legally obliged to hold a copy of an asbestos register for each property in their portfolio. As this application relates to an intended residential use, the Council needs to be satisfied that if any asbestos previously identified is still present, it is either removed or suitably managed to minimise risk to human health as there is no safe threshold for asbestos exposure. A copy of the asbestos register and where appropriate, any remedial strategy, must be provided in writing to the Local Planning Authority prior to any works commencing. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Informatives:

- The granting of this planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of the Environmental Protection Act 1990 be received. For further information please contact the Environmental Health Department on **01903 737555**.
- The applicant's attention is drawn to the requirements of the Environmental Protection Act, 1990 and the Clean Air Act, 1993 with regard to burning on site. A statutory nuisance may be caused by smoke and/or ash from fires or noise from the cutting and/or chipping of trees. In addition, air quality could be adversely affected on large projects. The granting of this planning permission does not permit a statutory nuisance to be caused. The Environment Agency should be contacted regarding Exemption Permits to burn on site.

Many thanks,

Kate.

Kate Giddings
Senior Technical Officer
Environmental Health

T: 01903 737586
E: kate.giddings@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

