

Zara Camp

From: Graham Evans
Sent: 03 December 2008 10:16
To: Planning.Responses
Subject: FW: Planning Consultation on: FP/231/08/

There is insufficient information in the application to enable the determine the sound pressure level from the A/C unit at the nearest noise sensitive premises, believed to be a first floor flat above the shop? However it appears from photographs that the external A/C unit has already been installed alongside two existing A/C units that have not given rise to previous complaint. It is assumed that the A/C unit will only be operational during shop opening hours and it is therefore unlikely that the additional unit will have significant impact on local amenity by way of noise. No objections.

Graham Evans
Senior Environmental Health Officer
Arun District Council
01903 737694

From: John Green
Sent: 02 December 2008 16:49
To: Graham Evans
Subject: FW: Planning Consultation on: FP/231/08/

Please respond direct, to planning.responses@arun.gov.uk
171908
Thanks,
John
ext 37693

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 01 December 2008 18:01
To: EH Planning Consultations
Subject: Planning Consultation on: FP/231/08/

To: Environmental Health - John Green

NOTIFICATION FROM ARUN DISTRICT COUNCIL**TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION FP/231/08/
NO:

Registered: 27-NOV-08
Site 108 Felpham Road Bognor Regis
Address:

Grid Reference: 095115-499990

Category: Plan Applicat'n

Description of Works: Internal shopfit including installation of airconditioning system and associated external condenser.

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 01-JAN-09. You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Ms A Paice who can be contacted on telephone number 01903 373756 x 37314.

Thanking you in anticipation

consultee_email
