



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 04 December 2020 13:12

To: Planning.Responses <Planning.Responses@arun.gov.uk>; Amber Willard <Amber.Willard@arun.gov.uk>

Subject: Abergail Clyde Road Felpham PO22 7AH - FP/231/20/PL

Planning Application Reference: FP/231/20/PL

Proposal: New building with first floor 1 No. 1- bed apartment above (3 x No.) garages a & cycle store with parking. This site is in CIL Zone 4 (Zero Rated) as flat

Address: Abergail Clyde Road Felpham PO22 7AH

Dear Amber,

Environmental Health has no objection in principle to the above proposal, however the following matters must be considered:

Asbestos

The owner(s) of any domestic property built or refurbished before the year 2000 are legally obliged to protect householders from any risks from work activities being carried out in their homes. Where the work being carried out involves Asbestos-Containing Materials (ACM's), then the Control of Asbestos Regulations 2012 will apply. As the proposed development is being demolished and / or renovated, the Council need to be satisfied that any ACM's previously identified as still present, is either removed or suitably managed to minimise risk to human health as there is no safe threshold for asbestos exposure.

Within any owner-occupied domestic properties, the owner(s) are not legally responsible for risks to contractors from asbestos, as the owners themselves are not engaged in any work activity.

NB: If you are planning any DIY home improvements, repairs or maintenance – and intend to bring in any additional builders, maintenance workers or contractors to site – you must inform them of any ACM's in your home before they start work. This will help reduce the risks of any ACM's being disturbed. The

domestic enforcement authority; the Health and Safety Executive (HSE) strongly encourages the use of trained professionals to repair or remove ACM's. If an owner / occupier chooses to carry out DIY repairs or remove damaged asbestos materials themselves, they must make sure the right Personal Protective Equipment (PPE) is used and always follow safe working methods. In addition, please be aware that ACM's need to be legally disposed of as 'hazardous waste'. The removed materials should not be mixed with normal household waste. Arrangements must be made to have any ACM's collected by a competent person(s) or there may be special facilities in an area where you can safely dispose of it.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031.

Construction

No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:

- a) An indicative programme for carrying out of the works;
- b) Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
- c) Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
- d) Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
- e) The parking of vehicles of site operatives and visitors;
- f) Loading and unloading of plant and materials, including permitted times for deliveries;
- g) Storage of plant and materials used in constructing the development;
- h) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- i) The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
- j) Measures to control the emission of dust and dirt during construction;
- k) A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Noise

No information has been provided assessing the potential noise impact from nearby adjacent commercial uses including deliveries and plant / equipment.

I therefore recommend that in order for this section to make an informed comment the applicant should be requested to provide further information assessing the noise impact of the external noise sources on the proposed residential accommodation. The report should include, if appropriate, measures to be taken to mitigate excess noise impact.

The report should be prepared by a person with appropriate acoustic qualifications and should be with full regard to all relevant guidance including BS8233:2014 – ‘Guidance on Sound Insulation and Noise Reduction for Buildings’ and BS4142:2014+A1:2019 ‘Methods for rating and assessing industrial and commercial sound’.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Thank you for your consultation,

Sincerely, Craig

Craig Milligan
Environmental Health Officer
Technical Services

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

