

Susan Leeson

From: Graham Evans
Sent: 28 January 2014 16:16
To: 'ali hiron's'
Cc: Nick Howard; Susan Leeson
Subject: RE: The Fox FP/232/13/

Dear Mrs Hiron's,

Further information to support your planning application should be passed to the planning officer dealing with your application when it is available. The planning officer will be able to advise you of any time constraints on your application.

Regards

Graham Evans | Senior Environmental Health Officer, Pollution Team, [Arun District Council](#) | Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37694 | External: +44 (0) 1903 737694 | E-mail: graham.evans@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: ali hiron's [REDACTED]
Sent: 28 January 2014 16:06
To: Graham Evans
Subject: RE: The Fox FP/232/13/

Dear Mr Evans,

I am writing to inform you of the progress with the issues raised and the completion of the form you sent in. Most of the form has been completed however we are not having any joy getting hold of the details of the extractor from the gentleman who's putting it in, as we have been unable to reach him so far (we think he might be away). We just wanted you to know we are trying to get it sorted but its taking a long time to get people to contact us back.

kind regards
Alison and Andy Hiron's
The Fox

From: Graham.Evans@arun.gov.uk
[REDACTED]
CC: Nick.Howard@arun.gov.uk
Subject: The Fox
Date: Wed, 22 Jan 2014 11:49:50 +0000

Dear Mrs Hiron's,

I have reproduced my planning consultation response below as discussed & attached guidance. Should you wish to discuss further please contact me in respect of noise issues, or Nick Howard on the Food Team (01903 737685) in respect of odour/food hygiene issues, as appropriate.

Regards

Graham Evans | Senior Environmental Health Officer, Pollution Team, Arun District Council | Location: Third Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37694 | External: +44 (0) 1903 737694 | E-mail: graham.evans@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Graham Evans

Sent: 21 January 2014 08:31

To: Planning.Responses

Cc: Nick Howard

Subject: FW: Planning Consultation on: FP/232/13/

Insufficient information is provided in respect of the kitchen extract system The applicants attention should be drawn to the attached guidance, more detailed guidance is available at https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/69280/pb10527-kitchen-exhaust-0105.pdf . In addition to the above the distance from the extract system to the nearest sensitive receptors, and the nature of these premises, is unclear.