



Please see Action Sheet



Hi Simon,


Thank you for the email.

I can confirm that there is space for at least 3 x cars on the plot if needed and that is without the use of the garage – I attach a copy of the plot plan showing this, I trust that this is ok.

By all means contact me if you have further queries.

Kind regards,

Chris Moore



Dear Chris,

Can you confirm the number of parking spaces now proposed please. I note that FP/195/18/PL stated two spaces however, with the changes to the access it is not clear how many can be accommodated off road. Please also be aware that as according to our new Parking Standards SPD, the requirement in this location for a 4 bed dwelling would be 3 spaces and the garage cannot be included as it measures less than 3m by 6m.


Kind Regards



ARUN
DISTRICT COUNCIL

CIL is coming
find out more...
www.arun.gov.uk/CIL

Community
Infrastructure
Levy



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.