

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 21 May 2021 10:33

To: Michael Eastham <Michael.Eastham@arun.gov.uk>

Subject: RE: *EXTERNAL: Planning application FP/248/20/PL - Sports Pitches and Changing Facilities Building, Site 6, Felpham

Hi Michael,

I have reviewed the amended CMP including the additional measures for control of noise and vibration. The section describing the control factors appears rather vague in stating 'noise and vibration will be kept to a minimum whenever possible...' BS5228:2009 includes specific measures for reducing noise from construction, including measures such as using modern equipment, fitting mufflers / silencers / baffles to noisy equipment, the use of acoustic barriers, etc..

I would recommend the applicant be requested to outline specific measures (in accordance with BS5228:2009) that are enforceable so that in the event any noise complaints are received; we can assess whether the agreed control measures are in place – such as mufflers and acoustic barriers etc.

Furthermore, the public engagement strategy should include notification of dates and times of scheduled works to premises likely to be impacted from noise & vibration from piling works / construction works.

Regards
Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

