

From: Daun Johnson
Sent: 09 January 2020 14:20
To: Planning Scanning
Subject: FW: FP/251/19/PL - For the attention of Mrs D Johnson
Attachments: 2261.7.200 revA site and block plan.pdf; 2261.7.201 revA existing and proposed plans.pdf; Screen Shot 2020-01-09 at 09.24.06.png

Daun Johnson | Technical Support Unit Assistant, Directorate of Place, Arun District Council | Location: GroundFloor, Phoenix House, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Daun Johnson
Sent: 09 January 2020 09:36
To: Daun Johnson
Subject: FW: FP/251/19/PL - For the attention of Mrs D Johnson

Daun Johnson | Technical Support Unit Assistant, Directorate of Place, Arun District Council | Location: GroundFloor, Phoenix House, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Joanne Massey
Sent: 09 January 2020 09:28
To: Planning <>
Cc: Andy Waters <>
Subject: FP/251/19/PL - For the attention of Mrs D Johnson

Dear Mrs Johnson,

I am writing to you regarding the 'further information request' which we received on 24/12/2019 and following our conversation earlier.

- I have attached an amended location plan which shows the full boundary line of the site.
- Regarding the bin store, it is simply a porous tarmac hardstanding which the existing bins will be placed on, there isn't anything to elevate. The fencing and gates surrounding the area will be like for like with the existing fencing of the school.
- The tarmac will be Topmix **Permeable** from **Tarmac** installed on top of an aggregate sub-base onto a capping layer. This allows rainwater to drain through the wearing surface.
- The visibility splay has been added to drawing of the proposed new vehicular entrance. [drawing no. 2261.7.201 rev A].

- I have also attached an extract from an email fro West Sussex County Council Highways, detailing the permission to proceed with the works after having already provided the license.

If you require any further information, please do let me know when you can.

Kind regards,

Joanne Massey
Architectural Assistant
Felce & Guy Partnership LLP
Studio 5
English Close
Hove
BN3 7ET



Think of the environment, and consider whether it is necessary to print out this email before doing so.

This email is intended solely for the use of the individual to whom it is addressed and may contain confidential and/or privileged material. If you are not the intended recipient, be advised that you have received this email in error and that any use, dissemination, forwarding, printing or copying of this email is strictly prohibited. Whilst this message has been checked for viruses, we cannot accept liability for any damage sustained as a result of software viruses and advise that you carry out your own virus checks before opening any attachment.

Felce and Guy Partnership LLP is a Limited Liability Partnership incorporated in England and Wales under the Limited Liability Partnership Act 2000 Registered Partnership number OC 311799 Registered Office: Unit 5, English Business Park, English Close, Hove BN3 7ET.

Bishop - [REDACTED]

Thursday, 28 November 2019 09:01

De Massey [REDACTED]

Re: Bishop Tufnell School vehicle crossover - 3011918

Hi,

Thank you for your email. In terms of planning as Pennyfields is an unclassified road so from a highway
view you can start the crossover works. This license has already been issued, you are free to
work whenever you like.

You should have received the VCO pack from our admin team already, this contained the list of appropr
ators. If you have not received this info please let me know.

Regards

De
Edward
Infrastructure and Environment
and Transport
West County Council

problem with a road or pavement or raise a highways related enquiry

at  @WSHighways