

[REDACTED]

From: Simon Davis
Sent: 22 May 2019 16:34
To: Planning Scanning
Subject: FW: Planning Consultation on FP/42/19/DOC

[REDACTED]

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Lauren Wiltshire [REDACTED]
Sent: 22 May 2019 13:51
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Subject: RE: Planning Consultation on FP/42/19/DOC

Good afternoon Simon,

My sincere apologies in delay in getting back to yourself and Laura, I have been away and now playing catch up.

I have chased my engineers for a response which I am hoping to have by end of the week at the very latest.

On another note, has an invoice been produced for the S106 payments? If not is this something you could assist with?

Kind regards,

Lauren Wiltshire
Head of Technical

Hampshire Homes Group

8 Chalmers Estate | Crawley Hill | Nr Romsey | Hampshire | SO51 6AP

[REDACTED]



From: Simon Davis [REDACTED]
Sent: 21 May 2019 16:07
To: Lauren Wiltshire [REDACTED]

Cc: Laura Gibbons [REDACTED]
Subject: RE: Planning Consultation on FP/42/19/DOC

Dear Lauren,

I do not appear to have received any response since Laura's email below. We need to bring this application to a close soon so I am giving you a period of 2 weeks to provide your response to Laura's earlier comments. If you cannot meet this deadline then we will have to refuse to discharge these drainage conditions (and at the same time I will determine the other conditions).

Please note that if works have commenced then it may then be necessary to serve a temporary stop notice until the drainage matters have been agreed.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons [REDACTED]
Sent: 26 April 2019 11:45
To: 'Lauren Wiltshire' [REDACTED]
Cc: Simon Davis [REDACTED]
Subject: RE: Planning Consultation on FP/42/19/DOC

Hi Lauren,

My comments to conditions 7, 9 and 10 are still outstanding, I have not seen any revised details. Condition 8 can be discharged.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Lauren Wiltshire [REDACTED]
Sent: 24 April 2019 13:43
To: Laura Gibbons
Cc: Simon Davis
Subject: RE: Planning Consultation on FP/42/19/DOC

Hi Laura,

Hope you are well?
Apologies for delay in response to below.

Are these comments now superseded with the approval of the OWC as it is my understanding all of these aspects have been actioned through discussions with Paul?

Kind regards,

Lauren

Lauren Wiltshire
Head of Technical

Hampshire Homes Group

8 Chalmers Estate | Crawley Hill | Nr Romsey | Hampshire | SO51 6AP

From: Simon Davis <[REDACTED]>
Sent: 15 March 2019 12:26
To: Lauren Wiltshire [REDACTED]
Subject: FW: Planning Consultation on FP/42/19/DOC

Dear Lauren,

I now have a response from our drainage engineer as set out below.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LE

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 15 March 2019 12:14
To: Planning.Responses [REDACTED]
Cc: Simon Davis [REDACTED]
Subject: RE: Planning Consultation on FP/42/19/DOC

Engineers Comments Regarding Condition 7

1. Catchpits must be provided upstream of all connections into the attenuation tank.
2. No construction detail drawings have been provided. Please provide construction detail drawings of manholes, catchpits, permeable paving, attenuation tank and hydrobrake.
3. There is conflict between the landscaping proposals and the drainage proposals. Trees must not be located on or near attenuation tanks. Please revise the landscaping proposals.

Comments regarding Condition 8

I will consult with my colleague Paul Cann regarding the progress of the ordinary watercourse land drainage consent.

Comments Regarding Condition 9

No maintenance manual has been provided. Please provide a site specific maintenance manual which meets the requirements of this condition.

Comments Regarding Condition 10

Proposed property boundaries for plots 12-14 need to be amended to allow access to the watercourse. 3m easement is required from any building, fence or wall and the top of bank of an ordinary watercourse.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.