

[REDACTED]

From: Lauren Wiltshire [REDACTED]
Sent: 31 May 2019 11:30
To: Josh Ward [REDACTED]; Jon Ash [REDACTED]
Cc: Simon Davis <Simon.Davis@arun.gov.uk>; Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Subject: RE: Planning Consultation on FP/42/19/DOC

Good morning all,

Please see my comments/instructions below.

Kind regards,

Lauren Wiltshire
Head of Technical

Hampshire Homes Group

8 Chatmohr Estate | Crawley Hill | Nr Romsey | Hampshire | SO51 6AP

[REDACTED]



From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 31 May 2019 11:26
To: Lauren Wiltshire [REDACTED]
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Consultation on FP/42/19/DOC

Lauren,

Thank you for your email. I have the following comments:

1. The construction detail drawings of the attenuation tanks needs to show the impermeable membrane around the tank, between the tank and the coarse sand bedding. MJA to update
2. Can the catchpits please be labelled on plan. MJA to update
3. 3m easement is not being provided to the watercourse at plots 12, 13 and 14. Please can this be provided. Or as a minimum demountable fences provided. Yes landscaping to include on layout

4. Please can the proposed landscaping plans be amended to remove the trees at the end of the parking area between plots 12 and 11/10? Trees are proposed directly in the location of the control chamber and in close proximity to the lined tank. Yes landscaping to update

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.