

Katherine Rawlins

From: Ian.Hayward [REDACTED]
Sent: 14 May 2012 15:39
To: Katherine Rawlins
Subject: Additional response to application FP/47/12 - 14 Felpham Way Felpham, Removal of old concrete driveway and replace with permeable brick block paving

This consultation has been dealt with by **SRU**

Reference No: FP/47/12

District Office: Arun

Response: Advice

FP/47/12 - 14 Felpham Way Felpham, Removal of old concrete driveway and replace with permeable brick block paving

Afternoon Katherine,

Following on from our phone conversation this morning please find an additional response to the above planning application.

"It has come to my attention that since my initial response on this planning application, dates 08/05/2012, the constructed driveway is not permeable and does slope towards the public highway. I would therefore request that suitable drainage methods are installed to prevent private surface water running onto the public highway. This is in the interest of highway safety. From the information supplied I believe the applicant is prepared to provide the appropriate drainage facilities."

Ian Hayward
 Strategic Planning

<u>Ian Hayward</u> Senior Technician, Monitoring and Records, Strategic Planning, Communities & Infrastructure, <u>West Sussex County Council</u> Location: 2nd Floor, Northleigh, Chichester, PO19 1RH

Think sustainably. Do you have to print? Can you double side? Do you need colour?

--
 This e-mail and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure e-mails and attachments are virus-free but you should carry out your own checks before opening any attachment.