

Katherine Rawlins

From: Brian Holland
Sent: 30 April 2012 13:03
To: Katherine Rawlins
Subject: RE: FP/47/12 14 Felpham Way
Katherine

The WSCC highways should be consulted. The requirement is for no water to be discharged from private areas onto the public highway and therefore I would expect WSCC to object. If this is a large area (say in excess of 25 sq. metres) then perhaps you could consult us later when the drainage proposals are submitted.

Brian H

Brian Holland | Engineering Services Manager, Greenspace, Engineering & Emergency Planning, Arun District Council |
Location: 2nd Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Arun and Chichester District Council coast protection and land drainage services are working in partnership

Visit our web sites at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: Katherine Rawlins
Sent: 30 April 2012 12:12
To: Brian Holland
Subject: FP/47/12 14 Felpham Way

Hi Brian,

I have a retrospective application for a driveway. The driveway slopes down to the road and there is no soakaway provided.

Given that the drive slopes onto the highway and this is impermeable paving, do you wish to be consulted on this application?

Katherine

Katherine Rawlins | Senior Planning Officer, Planning Services, Arun District Council | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.