

**From:** Simon Davis

**Sent:** 20 April 2021 14:17

**Subject:** FP/80/21/DOC - Mow Cottage, Worms Lane, Felpham

Dear Wayne,

Our Environmental Health Officer has stated in respect of the lighting that:

“With regard to the above application, the submissions do not appear to include any information about the height, position or aiming angles of each installation, nor any detail regarding beam orientation or light spillage, as required by the condition. It is therefore not currently possible to consider the discharge of this condition.”

Please provide full details of the on-site lighting including details of the fixtures and fittings and where lights are proposed to be.

Kind Regards

**Simon J Davis MRTPI**  
Principal Planning Officer  
Directorate of Place

**T:** 01903 737874

**E:** [simon.davis@arun.gov.uk](mailto:simon.davis@arun.gov.uk)



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF  
[www.arun.gov.uk](http://www.arun.gov.uk)

To register to receive notification of planning applications in your area please go to  
[www.arun.gov.uk/planning](http://www.arun.gov.uk/planning)

Arun is a CIL Charging Authority, for more information go to [www.arun.gov.uk/cil](http://www.arun.gov.uk/cil)

Sign up to our newsletter [here](#)

