

Sandra Edwards

From: Amanda Scholes on behalf of Planning.Responses
Sent: 06 August 2018 08:52
To: Planning Scanning
Subject: FW: F/10/18/P Waterbury House Ford Road Ford BN18 0BH - Planning Application External / Arun Council / (Sussex) 21.6.2018 complete

F/10/18/PL

From: Medlock Ben [REDACTED] **On Behalf Of** Town Planning SE
Sent: 03 August 2018 09:19
To: Planning.Responses
Cc: Town Planning SE
Subject: F/10/18/P Waterbury House Ford Road Ford BN18 0BH - Planning Application External / Arun Council / (Sussex) 21.6.2018 complete

Dear Planning,

Thank-you for consulting Network Rail on the below application. Please find below our informative comments below.

Due to the proposal being in close proximity to Network Rail we request the Developer contacts Asset Protection – London South East Team - email AssetProtectionSussex@networkrail.co.uk to agree an Asset Protection Agreement with us for any work in the vicinity of Network Rail land and infrastructure. We include a standard response for information and more information can also be obtained from our website at <https://www.networkrail.co.uk/communities/lineside-neighbours/working-by-the-railway/>

We also note that it is close proximity to a level Crossing and would need to review and be assured that any plans and works including access and traffic management plans during Construction works will have no detrimental effect to the safe use of this.

The Developer must ensure that their proposal, both during construction and after completion of works on site, does not:

- encroach onto Network Rail land
- affect the safety, operation or integrity of the company's railway and its infrastructure
- undermine its support zone
- damage the company's infrastructure
- place additional load on cuttings
- adversely affect any railway land or structure
- over-sail or encroach upon the air-space of any Network Rail land
- cause to obstruct or interfere with any works or proposed works or Network Rail development both now and in the future

The developer should comply with the following comments and requirements for the safe operation of the railway and the protection of Network Rail's adjoining land.

Future maintenance

The development must ensure any future maintenance can be conducted solely on the applicant's land. The applicant must ensure that any construction and any subsequent maintenance can be carried out to any proposed buildings or structures without adversely affecting the safety of, or encroaching upon Network Rail's adjacent land and air-space, and therefore all/any building should be situated at least **2 metres (3m for**

overhead lines and third rail) from Network Rail's boundary. The reason for the 2m (3m for overhead lines and third rail) stand off requirement is to allow for construction and future maintenance of a building and without requirement for access to the operational railway environment which may not necessarily be granted or if granted subject to railway site safety requirements and special provisions with all associated railway costs charged to the applicant. Any less than 2m (3m for overhead lines and third rail) and there is a strong possibility that the applicant (and any future resident) will need to utilise Network Rail land and air-space to facilitate works. The applicant / resident would need to receive approval for such works from Network Rail Asset Protection, the applicant / resident would need to submit the request at least 20 weeks before any works were due to commence on site and they would be liable for all costs (e.g. all possession costs, all site safety costs, all asset protection presence costs). However, Network Rail is not required to grant permission for any third party access to its land. No structure/building should be built hard-against Network Rail's boundary as in this case there is an even higher probability of access to Network Rail land being required to undertake any construction / maintenance works. Equally any structure/building erected hard against the boundary with Network Rail will impact adversely upon our maintenance teams' ability to maintain our boundary fencing and boundary treatments.

Drainage

Storm/surface water must not be discharged onto Network Rail's property or into Network Rail's culverts or drains except by agreement with Network Rail. Suitable drainage or other works must be provided and maintained by the Developer to prevent surface water flows or run-off onto Network Rail's property. Proper provision must be made to accept and continue drainage discharging from Network Rail's property; full details to be submitted for approval to Network Rail Asset Protection. Suitable foul drainage must be provided separate from Network Rail's existing drainage. Soakaways, as a means of storm/surface water disposal must not be constructed near/within 10 – 20 metres of Network Rail's boundary or at any point which could adversely affect the stability of Network Rail's property. After the completion and occupation of the development, any new or exacerbated problems attributable to the new development shall be investigated and remedied at the applicants' expense.

Plant & Materials

All operations, including the use of cranes or other mechanical plant working adjacent to Network Rail's property, must at all times be carried out in a "fail safe" manner such that in the event of mishandling, collapse or failure, no plant or materials are capable of falling within 3.0m of the boundary with Network Rail.

Scaffolding

Any scaffold which is to be constructed within 10 metres of the railway boundary fence must be erected in such a manner that at no time will any poles over-sail the railway and protective netting around such scaffold must be installed. The applicant/applicant's contractor must consider if they can undertake the works and associated scaffold/access for working at height within the footprint of their property boundary.

Piling

Where vibro-compaction/displacement piling plant is to be used in development, details of the use of such machinery and a method statement should be submitted for approval to Network Rail Asset Protection prior to the commencement of works and the works shall only be carried out in accordance with the approved method statement.

Fencing

In view of the nature of the development, it is essential that the developer provide (at their own expense) and thereafter maintain a substantial, trespass proof fence along the development side of the existing boundary fence, to a minimum height of 1.8 metres. The 1.8m fencing should be adjacent to the railway boundary and the developer/applicant should make provision for its future maintenance and renewal without encroachment upon Network Rail land. Network Rail's existing fencing / wall must not be removed or damaged and at no point either during construction or after works are completed on site should the foundations of the fencing or wall or any embankment therein, be damaged, undermined or compromised in any way. Any vegetation on Network Rail land and within Network Rail's boundary must also not be disturbed. Any fencing installed by the applicant must not prevent Network Rail from maintaining its own fencing/boundary treatment.

Lighting

Any lighting associated with the development (including vehicle lights) must not interfere with the sighting of signalling apparatus and/or train drivers vision on approaching trains. The location and colour of lights must not give rise to the potential for confusion with the signalling arrangements on the railway. The developers should obtain Network Rail's approval of their detailed proposals regarding lighting.

Noise and Vibration

The potential for any noise/ vibration impacts caused by the proximity between the proposed development and any existing railway must be assessed in the context of the National Planning Policy Framework which hold relevant national guidance information. The current level of usage may be subject to change at any time without notification including increased frequency of trains, night time train running and heavy freight trains.

Vehicle Incursion

Where a proposal calls for hard standing area / parking of vehicles area near the boundary with the operational railway, Network Rail would recommend the installation of a highways approved vehicle incursion barrier or high kerbs to prevent vehicles accidentally driving or rolling onto the railway or damaging lineside fencing.

Network Rail strongly recommends the developer contacts Network Rail Asset Protection London South East at [REDACTED] prior to any works commencing on site, and also to agree an Asset Protection Agreement with us to enable approval of detailed works. More information can also be obtained from our website at [REDACTED]

Kind regards,

Benjamin Medlock
Town Planning Technician, Property MLPM
1 Eversholt Street, London, NW1 2DN
[REDACTED]
[REDACTED]

From: Wicks Douglas
Sent: 22 June 2018 10:38
To: Town Planning SE; Asset Protection Sussex; Gonzales Giselle; Broyad Toby; Day Steve; Seward William
Subject: RE: F/10/18/P Waterbury House Ford Road Ford BN18 0BH - Planning Application External / Arun Council / (Sussex) 21.6.2018

Ben

Due to the proposal being in close proximity to Network Rail we request the Developer contacts Asset Protection – London South East Team - email [REDACTED] to agree an Asset Protection Agreement with us for any work in the vicinity of Network Rail land and infrastructure. We include a standard response for information and more information can also be obtained from our website at [REDACTED]

We also note that it is close proximity to a level Crossing and would need to review and be assured that any plans and works including access and traffic management plans during Construction works will have no detrimental effect to the safe use of this.

Regards
Doug
Doug Wicks
Scheme Project Manager
Asset Protection - South East
[REDACTED]

From: Medlock Ben **On Behalf Of** Town Planning SE

Sent: 14 June 2018 15:47

To: Town Planning SE; Asset Protection Sussex; Wicks Douglas; Gonzales Giselle; Broyad Toby; Day Steve; Seward William

Subject: F/10/18/P Waterbury House Ford Road Ford BN18 0BH - Planning Application External / Arun Council / (Sussex) 21.6.2018

Dear All,

Please see application below if you have any comments please advise by the 21.6.2018. The site is located close to Ford Station.

Description

Construction of 5 No. 1 bedroom flats together with staff accommodation, hard landscaping & parking, (resubmission following F/29/17/PL). This application affects the setting of a listed building & is a Departure from the Development Plan.


Link

[REDACTED]

Key issues

- Clearance site located close to site
- Close to Ford CCTV LC
-

GIS



Google



Site plan

E ben.medlock [REDACTED]

From: [planning.responses@arun.gov.uk](#) [REDACTED]
Sent: 21 May 2018 14:18
To: Town Planning SE
Subject: Acknowledgement of Planning Application: F/10/18/PL : Waterbury House

<http://www.arun.gov.uk>
NLPG UPRN 100062237016
DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office
Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN

