




from
**Southern
Water** 

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref

F/11/19/PL

Our ref

PLAN-028456

Date

04/07/2019

Contact



Dear Sirs,

Proposal: Construction of agricultural barn with flexible storage use (B8 Use Class) with ancillary office space.

Site: Wicks Farm, Ford Lane, Ford, BN18 0DF.

F/11/19/PL


Thank you for your letter of 04/06/2019.

The proposed development is some distance from the nearest public foul sewer. The applicant should assure himself that he has adequate rights to utilise the intervening private drainage systems. Otherwise the connection to the public sewerage system could be requisitioned under the terms of the Water Industry Act.

Southern Water requires a formal application for a connection to the foul sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructure-charges>.



The planning application form makes reference to drainage using Sustainable Urban Drainage Systems (SUDS).

Under current legislation and guidance SUDS rely upon facilities which are not adoptable by sewerage undertakers. Therefore, the applicant will need to ensure that arrangements exist for the long term maintenance of the SUDS facilities. It is critical that the effectiveness of these systems is maintained in perpetuity. Good management will avoid flooding from the proposed surface water system, which may result in the inundation of the foul sewerage system. Thus, where a SUDS scheme is to be implemented, the drainage details submitted to the Local Planning Authority should:

Specify the responsibilities of each party for the implementation of the SUDS scheme

Specify a timetable for implementation

Provide a management and maintenance plan for the lifetime of the development. This should include the arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime.

The application details for this development indicate that the proposed means of surface water drainage for the site is via a watercourse. The Council's technical staff and the relevant authority for land drainage consent should comment on the adequacy of the proposals to discharge surface water to the local watercourse.

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

For further advice, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW [REDACTED] www.southernwater.co.uk or by [REDACTED]

Yours sincerely

[REDACTED]

Luis Silva
Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU9903NW

Scale: 1:3856

Screen Print

ARUN DISTRICT COUNCIL F11/19/PL

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unlabeled (HOK) materials may include Bonded Asbestos Cement



N

Printed By: krispad

Date: 27-6-2019

Southern Water MapGuide Browser

Requested By:

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU9903NE

Scale: 1:3856

Screen Print

ARUN DISTRICT COUNCIL F11/19/PL

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UKO) materials may include Bonded Asbestos Cement



Printed By: krispad

Date: 27-6-2019

Southern Water MapGuide Browser

Requested By:

N

