

From: Amanda Scholes on behalf of Planning.Responses
Sent: 21 May 2019 09:14
To: Planning Scanning
Subject: FW: F/13/19/PL - Unit 1, Ford Lane Business Park, Ford Lane, Ford, BN18 0UZ

From: Kate Giddings
Sent: 20 May 2019 12:23
To: Andrew Wood
Cc: Planning.Responses; Anna Appleton
Subject: F/13/19/PL - Unit 1, Ford Lane Business Park, Ford Lane, Ford, BN18 0UZ

Good afternoon,

Further to the above application, please may EH make the following comments:

- Works of demolition or construction, including the use of plant and machinery, necessary for the implementation of this consent shall be limited to the following times:
08.00 – 18.00 hours Monday to Friday
08.00 – 13.00 hours Saturday
No work permitted on Sunday or Bank Holidays

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

- No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:
 - a. An indicative programme for carrying out of the works
 - b. Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works
 - c. Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s)
 - d. Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination
 - e. the parking of vehicles of site operatives and visitors
 - f. loading and unloading of plant and materials, including permitted times for deliveries
 - g. storage of plant and materials used in constructing the development
 - h. the erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate
 - i. the provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders)
 - j. measures to control the emission of dust and dirt during construction

k. a scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted

Reason: *To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031*

- No external lighting shall be installed until details have been submitted to, and approved in writing by the Local Planning Authority prior to the commencement of the development. This submission shall include a layout plan with beam orientation and a schedule of light equipment proposed (luminaire type; mounting height; aiming angles and luminaire profiles). The approved scheme shall be installed, fully assessed by a competent individual when operational to ensure no light creep / bleed, maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to the variation.

Reason: *To protect the appearance of the area / the environment and wildlife / local residents from light pollution.*

- If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented. If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason: *To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011-2031*

- Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:
 1. A 'Preliminary Risk Assessment' which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; and potentially unacceptable risks arising from contamination at the site.
 2. A 'Site Investigation Scheme', based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
 3. Based on the 'Site Investigation Scheme' and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
 4. A 'Verification Report' providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority.

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a 'long-term monitoring and maintenance plan' for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority.

Reason: *To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031*

Please may the agent/applicant/planning also confirm whether the proposed hours of operation (of the business, not the demolition/construction work) are the same as any existing permission? If so, EH have no additional comments on this element.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.