

From: Daniel Goodhand [REDACTED]
Sent: 08 July 2025 20:51
To: Jessica Riches
Subject: Noise Assessment Review - Ford Airfield
Attachments: 3679_20250708_TechnicalMemo_vS1-0.docx; 3679_20250708_TechnicalMemo_vS1-0.pdf

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Jessica,

Please find attached my technical memo for Ford Airfield. There is a lot of information I have requested but in theory this should be readily available. But still, it may take them a bit of time to compile and they may be frustrated by it.

I am concerned by there not being individual BS 4142 assessments because this could highlight dwellings planned too close to industrial uses. The recycling site has specific protections in the Waste Local Plan as well. This all needs more detail set out in a clear and robust manner. The new spine road could be a new noise source - especially if noise is from road traffic using it as a link road. I am hopeful this will become clear in the applicant's response.

If you have any comments or questions or would like me to make any amendments, please give me a call. My mobile number is [REDACTED].

Regards

Daniel Goodhand
Goodhand Acoustics
[REDACTED]
[REDACTED]

www.goodhandacoustics.co.uk

