[redacted]

From: Paul Cann
Sent: 19 June 2017 15:00
To: Planning.Responses
Subject: RE: Planning Consultation on F/17/17/DOC

Condition no.3 cannot be discharged at this time, as a maintenance manual has not been provided.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at http://www.arun.gov.uk/ and www.chichester.gov.uk
Save the environment - think before you print.

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 14 June 2017 16:04
To: Paul Cann
Subject: Planning Consultation on F/17/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO:	**F/17/17/DOC**
Registered:	08-JUN-17
Site Address:	1 - 4 Holm Oaks Land adj Northwood House Burndell Road Yapton

Description of Works:	Application for approval of details reserved by condition imposed under previous planning permission F/15/16/PL relating to condition No. 3 (SUDs system), 4 (Landscaping Scheme) & 10 (Construction site set up)

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditons relating to your field of expertise.
Click here to view the Discharge of Condition application
Click here to view conditions on original application - click on decision tab

Should you have any comments to make, these should be sent by replying to this email by 28th June 2017.

www.arun.gov.uk/planning
Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.
In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email