

David Easton

From: Brian Holland
Sent: 22 September 2010 12:01
To: Planning.Responses
Cc: Eve Hearsey; Simon Power
Subject: RE: Planning Consultation on: F/18/10/ at Land adjacent to no. 36

Engineer's response:

Although the proposed works are located at the edge of Flood Zone 3, the proposed alterations to the site levels and other proposed anti-inundation measures would appear to be adequate. It is also apparent that no other suitable or practical location is available for siting this equipment. No objections.

Regards

Brian Holland
 Engineering Services Manager

From: [REDACTED]
Sent: 13 September 2010 16:31
To: Brian Holland
Subject: Planning Consultation on: F/18/10/ at Land adjacent to no. 36

To: **Engineering Services Manager**

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
 TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION NO: F/18/10/
Registered: 02-SEP-10
Site Address: Land adjacent to no. 36 Rodney Crescent Ford BN18 0BL

Grid Reference:

Category: West Sussex Cons
Description of Works: Application under Regulation 3 of the Town & Country Planning General Regulations 1992 for decommissioning of existing pumping station, incorporating demolition of existing pump house building and the provision of a replacement pump station compound and access. (This application will be determined by West Sussex County Council)

The Council have received the above planning application from West Sussex County Council. I shall be pleased to receive any observations you may wish to make.

[Click here to view documents available on our website](#)

Should you have any comments to make, these should be sent by replying to this email by 27th September 2010. You can also monitor the progress of this application through the Council web site:

[Click here to access West Sussex County Council web site and use search boxes to find the application.](#)

Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr J Smith who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Regards
Planning Case Officer

consulteeReg3_email
