

Essential maintenance is being carried out to the planning, building control and local land charges database during the week commencing 12 April 2021.

During this time there will be no public or staff access to any records held within this database, and it will not be possible to carry out any of the following tasks via the Arun website:

- Research planning and building control history
- View any planning applications, plans, agreements, tree preservation orders or competent persons data
- Submit building control applications
- Submit planning application comments
- Report any planning compliance issues

The publicity and consultation period for all planning applications that fall over this week will be extended by a further week to ensure no one is disadvantaged.

All other aspects of planning, building control and local land charges will be limited during this week and you are strongly advised to contact the individual departments before 12 April 2021 for specific restrictions during this time.

Amanda Scholes

T: 01903 737453

E: amanda.scholes@arun.gov.uk



To register to receive notification of planning applications in your area please go to
www.arun.gov.uk/planning

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **[here](#)**



From: Ian Stocks [REDACTED] **On Behalf Of** FRS Water and Access

Sent: 15 March 2021 15:35

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Large Development Hydrant Condition - F/1/21/PL Land to the North of The Towpath, South and East of Church Farm Ford

FAO: Mrs A Gardner

Dear Mrs Gardner,

Please find attached a planning condition for application no. F/1/21/PL for the requirement of additional fire hydrant(s) for the proposed development. This is to ensure that all dwellings on the proposed site are within 150 metres of a fire hydrant for the supply of water for firefighting.

Evidence will also be required that Fire Service vehicle access meets with the requirements identified in Approved Document B Volume 1 2019 Edition: B5 Section 13, including Table 13.1 and diagram 13.1.

Regards

Ian Stocks

Water & Access manager


Ian Stocks – Water and Access Manager

Water and Access Office

West Sussex Fire and Rescue Service West Sussex County Council

Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB

Living Our Values Every Day




Ian Stocks - Water & Access Manager

West Sussex Fire and Rescue Service West Sussex County Council

Location: Water and Access Office, Bognor Fire Station, West Meads Drive, Bognor Regis,
PO21 5TB

Living Our Values Everyday



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

WEST SUSSEX COUNTY COUNCIL
WEST SUSSEX FIRE AND RESCUE SERVICE

HYDRANT CONDITION CONSULTATION WITH PLANNING AUTHORITY

Date: 15/03/2021

To: Mrs A Gardner

From: Ian Stocks

Planning Ref: F/1/21/PL

Address: Land to the North of The Towpath, South and East of Church Farm Ford

Description: Change of use from agricultural land to use as open space (6 hectares) and education (10 hectares). This site also lies within the parish of Yapton, affects a Public Right of Way & is in CiL zone 3 (Zero Rated) as other development.

Date of visit: N/A

RECOMMENDATION

Advice:	☒	Modification:	☐	More Information:	☐
Objection:	☐	No Objection:	☐	Refusal:	☐

Total number of hydrants required Unknown

This application has been dealt with in accordance with the statutory obligation placed upon Fire and Rescue Service by the following act;

***Fire and Rescue Services Act 2004
Part 5, 38: Duty to secure water supply etc.***

- 1) *A fire and rescue authority must take all reasonable measures for securing that an adequate supply of water will be available for the authority's use in the event of fire.*

This proposal has been considered by means of desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC mapping and Fire and Rescue Service information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments:

- 1) Prior to the commencement of the development details showing the proposed location of the required fire hydrants shall be submitted to and approved in writing by the Local Planning Authority in consultation with West Sussex County Council's Fire and Rescue Service. These approvals shall not be unreasonably withheld or delayed.
- 2) Prior to the first occupation of any dwelling/unit forming part of the proposed development that they will at their own expense install the required fire hydrants (or in a phased programme if a large development) in the approved location to BS 750 standards or stored water supply and arrange for their connection to a water supply which is appropriate in terms of both pressure and volume for the purposes of firefighting.

The fire hydrant shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

As part of the Building Regulations 2004, adequate access for firefighting vehicles and equipment from the public highway must be available and may require additional works on or off site, particularly in very large developments. (BS5588 Part B 5) for further information please contact the Fire and Rescue Service

If a requirement for additional water supply is identified by the Fire and Rescue Service and is subsequently not supplied, there is an increased risk for the Service to control a potential fire. It is therefore recommended that the hydrant condition is implemented

Reason: In the interests of amenity and in accordance with policy INF SP1 and TSP1 of the Arun Local Plan 2011-2031 and in accordance with The Fire & Rescue Service Act 2004.

Ian Stocks
Water and Access Manager

