

From: Amanda Scholes on behalf of Planning.Responses
Sent: 06 December 2019 09:10
To: Planning Scanning
Subject: FW: Planning Consultation on: F/22/19/PL

From: Joanne Lewis [REDACTED]
Sent: 05 December 2019 15:47
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: F/22/19/PL

No adverse comments from Environmental Health.

Joanne Lewis

Please note my normal working days are Wednesday, Thursday and Friday.

Joanne Lewis | Senior Environmental Health Officer, [Arun District Council](#) | Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [planning.responses](#) [REDACTED]
Sent: 04 December 2019 11:49
To: EH Planning Consultations <[REDACTED]>
Subject: Planning Consultation on: F/22/19/PL

To: Environmental Health - Planning consultation

NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Planning Permission

APPLICATION NO: F/22/19/PL

Registered: 4th December
2019

Site Address: Unit C5, C8, C9 Ford Airfield Industrial Estate Rollaston Park Ford
BN18 0HY

Grid Reference: 498943 103107

Description of Works: Over roofing of industrial units

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 05-JAN-20.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Andrew Wood who can be contacted on telephone number [REDACTED]

Regards
Planning Officer

consultee_email
