

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 10 October 2017 08:41
To: Planning Scanning
Subject: FW: Planning Consultation on F/26/17/DOC

From: Paul Cann
Sent: 09 October 2017 10:46
To: Planning.Responses
Subject: RE: Planning Consultation on F/26/17/DOC

Surface Water Drainage Comments;

The applicant will need to provide the following to support the proposals;

1. Full hydraulic calculations for the 1 in 100 year storm event + climate change allowance.
2. Full construction detail drawing of all drainage elements incl. permeable paving.
3. Specify pipe diameters and invert levels, etc.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

Sent: 13 September 2017 17:34

Subject: Planning Consultation on F/26/17/DOC

To: Engineers (Drainage)

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990**

**APPLICATION
NO:**

F/26/17/DOC

Registered:

08-SEP-17

Site Address:

1 - 4 Holm Oaks Land Adj to Northwood House Burndell Road
Ford

**Description of
Works:**

Application for approval of details reserved by condition
imposed under planning permission F/15/16/PL relating to
condition No. 3 (SuDs System and No. 4 (Landscaping
scheme)

The Council have received the above application to discharge conditions. I shall be
pleased to receive any observations you may wish to make in respect of those
conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 27th September 2017.

www.arun.gov.uk/planning

**Please be aware that any comments you may make will be available on our website so
please do not insert personal details or signatures on your reply.**

In the absence of a reply within the period stated, I shall assume that you have no
observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on
telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
