



Planning and Development Services  
Arun District Council  
Arun Civic Centre  
Maltravers Road  
Littlehampton  
West Sussex  
BN17 5LF

Developer Services  
Southern Water  
Sparrowgrove House  
Sparrowgrove  
Otterbourne  
Hampshire  
SO21 2SW

Your Ref  
F/29/18/DOC  
Our Ref  
PLAN-026807  
Date  
19/02/2019

Dear Sirs,

**Proposal: Approval of details reserved by condition imposed under ref F/5/18/RES relating to Condition No 3 pumping station design and Condition No 4 details of the LEAP.**  
**Site: Land South Of Burndell Road, Yapton, BN18 0HR.**  
**F/29/18/DOC**

Thank you for your letter of 05/02/2019.

The principles of the design of the proposed foul pumping station are acceptable to Southern Water. It shall be noted that it is Southern Water's requirement to apply to this structure a non-habitable zone of 15 meters from the external edge of wet well.

Southern Water would have no comments to make with regards to condition 4 being subject of consultation.

Yours Sincerely

Marta Karpezo  
Developer Services

