

John Hall Consulting
113 Limmer Lane
Felpham
PO22 7LR

Date: 17th June 2022

Please ask for: Mrs A Gardner

Tel: 01903 737529

Your Ref:

Our Ref: F/5/22/DOC

Dear Mr Hall,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under F/7/21/PL relating to conditions 3-surface water drainage scheme, 4-discharge of flows to watercourses, 5-maintenance and management of surface water drainage, 6-landscape screening scheme, 7-contamination and 9-ecological enhancements.

Wicks Farm Ford Lane Ford BN18 0DF

Notification regarding the above application:

Condition Number 4

The development shall not proceed until details have been submitted to and approved in writing by the Local Planning Authority for any proposals: to discharge flows to watercourses; or for the culverting, diversion, infilling or obstruction of any watercourse on or adjacent to the site. Any discharge to a watercourse must be at a rate no greater than the pre-development run-off values and in accordance with current policies. No construction is permitted, which will restrict current and future landowners from undertaking their riparian maintenance responsibilities in respect to any watercourse or culvert on or adjacent to the site.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. And to ensure that the duties and responsibilities, as required under the Land Drainage Act 1991, and amended by the Flood and Water Management Act 2010, can be fulfilled without additional impediment following the development completion. It is considered necessary for this to be a pre-commencement condition to protect existing watercourses prior to the construction commencing.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

This condition is discharged in so far as submission of details relates and refers to the following details:

Construction Details 501 Rev B

Construction Details 502 Rev B

Downstream Defender Design Data
Downstream Defender Select
Site Layout Proposed Drainage and Levels101 Rev C
Technical Specification Hb01 and Hb02.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning