

From: Carol Reynolds
Sent: 05 May 2017 16:48
To: Planning.Responses
Subject: FW: Planning Consultation on: LU/103/17/PL

Environmental Health:

Demolition/Construction. No machinery shall be operated, no process shall be carried out and no deliveries taken or despatched on the site, except between the hours of 7:00 and 18:00 on Mondays to Fridays inclusive; 7:00 to 13:00 hrs on Saturdays and at no time at all on any Sunday, Public or Bank.

Acoustic Report. Before the development commences the applicant shall submit a suitable Acoustic Report prepared in accordance with the requirements of BS4142 designed to predict the noise levels at the nearest noise sensitive location which may be generated by the movement of trolley cages on site and any proposed mitigation intended to prevent detriment of the amenity. Should it further be the intention to provide a pharmacy at this premises, with concomitant external refrigeration unit, or to change the existing air conditioning unit, then these items to be included in the Acoustic Report assay. Such a report to be agreed to the satisfaction of this Department.

Hours of operation of this site to be limited to delivery hours as above.

C/N: 218557

Samantha Humphries | Administrative Assistant, Corporate Support
Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk Please Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 06 April 2017 14:33
To: EH Planning Consultations
Subject: Planning Consultation on: LU/103/17/PL

To: Environmental Health, Graham Evans/Sarah Meeton

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order
2015**

Planning Permission

APPLICATION LU/103/17/PL

NO:

Registered: 24th March
2017

Site Address: 12 Surrey Street Littlehampton BN17 5BG

Grid Reference: 502714 102122

Description of Works: New Shop front & internal alterations

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 11-MAY-17.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:
www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Regards
Planning Officer

consultee_email
