

[REDACTED]

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 18 May 2021 08:58
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: RE: Planning Consultation on: LU/111/21/DOC

Hi Anita,

Engineers Comments Regarding Condition 8

This condition was requested by Southern Water so their comments should be sought.

We would note the following:

- Catchpits should be provided upstream of connections into permeable paving.
- Finish and formation levels of permeable paving should be noted on plan.
- Construction detail drawings should be supplied. Including a construction detail of the permeable paving.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk or [REDACTED]

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 20 April 2021 09:50
To: Land Drainage <Land.Drainage@arun.gov.uk>
Subject: Planning Consultation on: LU/111/21/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: LU/111/21/DOC
Registered: 14th April 2021
Site Address: 46a & 47 Pier Road and Land North of Clifton Road Littlehampton BN17 5LW
Description of Works: Approval of details reserved by condition imposed under ref LU/287/17/PL relating to Condition Nos 7 - divert public sewers and 8 - foul & surface water sewerage disposal.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **5th May 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Mrs A Gardner

Planning Case Officer- Arun District Council

Telephone: 01903 737529

Email: Anita.Gardner@arun.gov.uk

PLCOND00 (ODS) 2020