


Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW



Your Ref
LU/121/17/RES
Our Ref
PLAN-018097
Date
18/05/2017

Dear Sirs,

Proposal: Approval of reserved matters following outline consent LU/47/11/ for construction of 126 No. dwellings together with internal road network, car parking & landscaping.

Site: Land North of Toddington Lane, Parcel C1 & part Parcels B2, B4 & C2 Littlehampton, BN17 7PP.
LU/121/17/RES

Thank you for your letter of 19/04/2017.

As previously advised, it has been agreed, as a temporary solution, that the maximum of 100 residential units can be allowed to be connected to the public sewerage system at manhole TQ02039914 prior to the provision of the foul network upgrading works.

No further flows from the proposed development will be allowed to discharge to the public sewer via temporary connection until such time as the Section 98 of the Water Industry Act legal agreement for requisition of the public sewer is signed.

The pumping of foul flows will have to be stopped during surcharged conditions in the foul sewerage network downstream and the developer will be responsible to provide arrangements to deal with the foul flows on the site. This will need to be automated using a sewer level monitor that is linked by telemetry to the pumping station.

The Council's Building Control officers/technical staff and the environment agency should be consulted regarding the discharge conditions 10, 11 and 12 for surface water disposal.

Southern Water Sparrowgrove House Otterbourne Winchester Hampshire SO21 2SW www.southernwater.co.uk

Southern Water Services Ltd Registered Office: Southern House Yeoman Road Worthing BN13 3NX Registered in England No.2368670



This initial assessment does not prejudice any future assessment or commit to any adoption agreements under Section 104 of the Water Industry Act 1991. Please note that non-compliance with Sewers for Adoption standards will preclude future adoption of the foul and surface water sewerage network on site.

Yours sincerely



Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: TQ0304SW

Scale: 1:4608

Screen Print

ARUN DISTRICT COUNCIL LD/12/17/RES

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (HOK) materials may include Bonded Asbestos Cement



Printed By: ganesas

Date: 11-5-2017

Southern Water MapGuide Browser

Requested By:

N

