



From: Tim Townsend [REDACTED]
Sent: 16 October 2017 10:23
To: Planning.Responses
Cc: Michael Eastham; Claire Potts
Subject: LU/121/17/REM - Landscaping comments

Dear Arun Planning,

Further to my response to you of 11th October 2017, please find some additional landscaping comments to be read-alongside that report:

With regard to the first point of the Persimmon response – south of Main Avenue and continuous verge – as the verge is adjacent to a retail/commercial element, a continuous verge would not be appropriate in this location.

With regard to the response on point 4 – it's BS8601, not 3601.

I trust this additional information assists.

I look forward to receiving response to all the points raised in due course.

Thank you.

Tim Townsend
Principal Planner, Highways – Planning Services
West Sussex County Council, Ground Floor Northleigh, County Hall, Chichester PO19 1RH

Web: www.westsussex.gov.uk

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.